



# Project Summary

## Entire House

### Authority Air Designs, LLC.

Job: Sample Address  
 Date: Oct 12, 2012  
 By: Joe Colburn  
 Plan: Sample Design

6608 W. 95th Place, Westminster, CO 80021-6422 Phone: (720) 354-8105 Fax: (720) 254-8105 Email: Joe@AuthorityAir.com Web: www.AuthorityAir.com

## Project Information

For: Sample Two  
 Sample Address, Denver, CO 80000  
 Phone: (720) 354-8105 Fax: (720) 354-8105  
 Web: www.SampleWebsite.com Email: Sample@Email.com

Notes:

## Design Information

Weather: Denver Stapleton Intl AP, CO, US

### Winter Design Conditions

Outside db	0 °F
Inside db	70 °F
Design TD	70 °F

### Summer Design Conditions

Outside db	91 °F
Inside db	75 °F
Design TD	16 °F
Daily range	H
Relative humidity	50 %
Moisture difference	-34 gr/lb

### Heating Summary

Structure	138300 Btuh
Ducts	12595 Btuh
Central vent (233 cfm)	14741 Btuh
Humidification	3683 Btuh
Piping	0 Btuh
Equipment load	169318 Btuh

### Sensible Cooling Equipment Load Sizing

Structure	51024 Btuh
Ducts	8341 Btuh
Central vent (230 cfm)	3293 Btuh
Blower	0 Btuh
Use manufacturer's data	n
Rate/swing multiplier	0.96
Equipment sensible load	60026 Btuh

### Infiltration

Method	Simplified	
Construction quality	Tight	
Fireplaces	1 (Tight)	
	<b>Heating</b>	<b>Cooling</b>
Area (ft²)	6930	4813
Volume (ft³)	49471	47377
Air changes/hour	0.13	0.07
Equiv. AVF (cfm)	107	55

### Latent Cooling Equipment Load Sizing

Structure	-453 Btuh
Ducts	-137 Btuh
Central vent (230 cfm)	-4385 Btuh
Equipment latent load	0 Btuh
Equipment total load	60026 Btuh
Req. total capacity at 0.70 SHR	7.1 ton

### Heating Equipment Summary

Make	n/a
Trade	n/a
Model	n/a
AHRI ref.	n/a
Efficiency	n/a
Heating input	
Heating output	0 Btuh
Temperature rise	0 °F
Actual air flow	0 cfm
Air flow factor	0 cfm/Btuh
Static pressure	0 in H2O
Space thermostat	n/a

### Cooling Equipment Summary

Make	n/a
Trade	n/a
Cond	n/a
Coil	n/a
AHRI ref.	n/a
Efficiency	n/a
Sensible cooling	0 Btuh
Latent cooling	0 Btuh
Total cooling	0 Btuh
Actual air flow	0 cfm
Air flow factor	0 cfm/Btuh
Static pressure	0 in H2O
Load sensible heat ratio	0

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



**Project Summary**  
**Basement Zone**  
 Authority Air Designs, LLC.

Job: Sample Address  
 Date: Oct 12, 2012  
 By: Joe Colburn  
 Plan: Sample Design

6608 W. 95th Place, Westminster, CO 80021-6422 Phone: (720) 354-8105 Fax: (720) 254-8105 Email: Joe@AuthorityAir.com Web: www.AuthorityAir.com

**Project Information**

For: Sample Two  
 Sample Address, Denver, CO 80000  
 Phone: (720) 354-8105 Fax: (720) 354-8105  
 Web: www.SampleWebsite.com Email: Sample@Email.com

Notes:

**Design Information**

Weather: Denver Stapleton Intl AP, CO, US

**Winter Design Conditions**

Outside db 0 °F  
 Inside db 70 °F  
 Design TD 70 °F

**Summer Design Conditions**

Outside db 91 °F  
 Inside db 75 °F  
 Design TD 16 °F  
 Daily range H  
 Relative humidity 50 %  
 Moisture difference -34 gr/lb

**Heating Summary**

Structure 3676 Btuh  
 Ducts 0 Btuh  
 Central vent (2 cfm) 150 Btuh  
 Humidification 184 Btuh  
 Piping 0 Btuh  
 Equipment load 4010 Btuh

**Sensible Cooling Equipment Load Sizing**

Structure 0 Btuh  
 Ducts 0 Btuh  
 Central vent (0 cfm) 0 Btuh  
 Blower 0 Btuh

Use manufacturer's data n  
 Rate/swing multiplier 0.96  
 Equipment sensible load 0 Btuh

**Infiltration**

Method Simplified  
 Construction quality Tight  
 Fireplaces 1 (Tight)

**Latent Cooling Equipment Load Sizing**

Structure 0 Btuh  
 Ducts 0 Btuh  
 Central vent (0 cfm) 0 Btuh  
 Equipment latent load 0 Btuh

Equipment total load 0 Btuh  
 Req. total capacity at 0.70 SHR 0 ton

	Heating	Cooling
Area (ft <sup>2</sup> )	536	0
Volume (ft <sup>3</sup> )	536	0
Air changes/hour	0.17	0
Equiv. AVF (cfm)	2	0

**Heating Equipment Summary**

Make  
 Trade  
 Model  
 AHRI ref

Efficiency 80 AFUE  
 Heating input 0 MBtuh  
 Heating output 0 Btuh  
 Temperature rise 0 °F  
 Actual air flow 0 cfm  
 Air flow factor 0 cfm/Btuh  
 Static pressure 0 in H2O  
 Space thermostat

**Cooling Equipment Summary**

Make  
 Trade  
 Cond  
 Coil  
 AHRI ref  
 Efficiency 0 SEER  
 Sensible cooling 0 Btuh  
 Latent cooling 0 Btuh  
 Total cooling 0 Btuh  
 Actual air flow 0 cfm  
 Air flow factor 0 cfm/Btuh  
 Static pressure 0 in H2O  
 Load sensible heat ratio 0

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



**Project Summary**  
**Conservatory Zone**  
**Authority Air Designs, LLC.**

**Job:** Sample Address  
**Date:** Oct 12, 2012  
**By:** Joe Colburn  
**Plan:** Sample Design

6608 W. 95th Place, Westminster, CO 80021-6422 Phone: (720) 354-8105 Fax: (720) 254-8105 Email: Joe@AuthorityAir.com Web: www.AuthorityAir.com

**Project Information**

**For:** Sample Two  
 Sample Address, Denver, CO 80000  
 Phone: (720) 354-8105 Fax: (720) 354-8105  
 Web: www.SampleWebsite.com Email: Sample@Email.com

**Notes:**

**Design Information**

**Weather:** Denver Stapleton Intl AP, CO, US

**Winter Design Conditions**

Outside db 0 °F  
 Inside db 70 °F  
 Design TD 70 °F

**Summer Design Conditions**

Outside db 91 °F  
 Inside db 75 °F  
 Design TD 16 °F  
 Daily range H  
 Relative humidity 50 %  
 Moisture difference -34 gr/lb

**Heating Summary**

Structure 19234 Btuh  
 Ducts 3710 Btuh  
 Central vent (41 cfm) 2626 Btuh  
 Humidification 3116 Btuh  
 Piping 0 Btuh  
 Equipment load 28686 Btuh

**Sensible Cooling Equipment Load Sizing**

Structure 15598 Btuh  
 Ducts 1726 Btuh  
 Central vent (41 cfm) 593 Btuh  
 Blower 0 Btuh  
 Use manufacturer's data n  
 Rate/swing multiplier 0.96  
 Equipment sensible load 17165 Btuh

**Infiltration**

Method Simplified  
 Construction quality Tight  
 Fireplaces 1 (Tight)

**Latent Cooling Equipment Load Sizing**

Structure -243 Btuh  
 Ducts -33 Btuh  
 Central vent (41 cfm) -789 Btuh  
 Equipment latent load 0 Btuh  
 Equipment total load 17165 Btuh  
 Req. total capacity at 0.85 SHR 1.7 ton

	Heating	Cooling
Area (ft <sup>2</sup> )	580	580
Volume (ft <sup>3</sup> )	9286	9286
Air changes/hour	0.15	0.08
Equiv. AVF (cfm)	24	13

**Heating Equipment Summary**

Make Carrier  
 Trade Carrier  
 Model 59SP5A060E17-14  
 AHRI ref 4702805

Efficiency 96.5 AFUE  
 Heating input 47520 MBtuh  
 Heating output 45936 Btuh  
 Temperature rise 51 °F  
 Actual air flow 1000 cfm  
 Air flow factor 0.044 cfm/Btuh  
 Static pressure 1.00 in H2O  
 Space thermostat

**Cooling Equipment Summary**

Make Carrier  
 Trade Comfort 13  
 Cond 24ABB324A31  
 Coil CNPVP3617A  
 AHRI ref 3250468

Efficiency 12.2 EER, 14.5 SEER  
 Sensible cooling 19890 Btuh  
 Latent cooling 3510 Btuh  
 Total cooling 23400 Btuh  
 Actual air flow 1000 cfm  
 Air flow factor 0.058 cfm/Btuh  
 Static pressure 1.00 in H2O  
 Load sensible heat ratio 1.00

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



# Project Summary

## Main Zone

### Authority Air Designs, LLC.

Job: Sample Address  
 Date: Oct 12, 2012  
 By: Joe Colburn  
 Plan: Sample Design

6608 W. 95th Place, Westminster, CO 80021-6422 Phone: (720) 354-8105 Fax: (720) 254-8105 Email: Joe@AuthorityAir.com Web: www.AuthorityAir.com

## Project Information

For: Sample Two  
 Sample Address, Denver, CO 80000  
 Phone: (720) 354-8105 Fax: (720) 354-8105  
 Web: www.SampleWebsite.com Email: Sample@Email.com

Notes:

## Design Information

Weather: Denver Stapleton Intl AP, CO, US

### Winter Design Conditions

Outside db	0 °F
Inside db	70 °F
Design TD	70 °F

### Summer Design Conditions

Outside db	91 °F
Inside db	75 °F
Design TD	16 °F
Daily range	H
Relative humidity	50 %
Moisture difference	-34 gr/lb

### Heating Summary

Structure	62844 Btuh
Ducts	0 Btuh
Central vent (107 cfm)	6773 Btuh
Humidification	7390 Btuh
Piping	0 Btuh
Equipment load	77007 Btuh

### Sensible Cooling Equipment Load Sizing

Structure	18004 Btuh
Ducts	0 Btuh
Central vent (107 cfm)	1529 Btuh
Blower	0 Btuh
Use manufacturer's data	n
Rate/swing multiplier	0.96
Equipment sensible load	18712 Btuh

### Infiltration

Method	Simplified
Construction quality	Tight
Fireplaces	1 (Tight)

	Heating	Cooling
Area (ft²)	3846	2265
Volume (ft³)	21941	20384
Air changes/hour	0.12	0.06
Equiv. AVF (cfm)	42	21

### Latent Cooling Equipment Load Sizing

Structure	-203 Btuh
Ducts	0 Btuh
Central vent (107 cfm)	-2035 Btuh
Equipment latent load	0 Btuh
Equipment total load	18712 Btuh
Req. total capacity at 0.85 SHR	1.8 ton

### Heating Equipment Summary

Make	Carrier
Trade	Carrier
Model	59SP5A100E21-20
AHRI ref	4702807
Efficiency	96.5 AFUE
Heating input	79200 MBtuh
Heating output	77616 Btuh
Temperature rise	61 °F
Actual air flow	1400 cfm
Air flow factor	0.022 cfm/Btuh
Static pressure	1.00 in H2O
Space thermostat	

### Cooling Equipment Summary

Make	Carrier
Trade	Comfort 13
Cond	24ABB330A31
Coil	CNPVP3621A
AHRI ref	3250525
Efficiency	10.8 EER, 13 SEER
Sensible cooling	23290 Btuh
Latent cooling	4110 Btuh
Total cooling	27400 Btuh
Actual air flow	1400 cfm
Air flow factor	0.078 cfm/Btuh
Static pressure	1.00 in H2O
Load sensible heat ratio	1.00

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



**Project Summary**  
**Upper Zone**  
**Authority Air Designs, LLC.**

**Job:** Sample Address  
**Date:** Oct 12, 2012  
**By:** Joe Colburn  
**Plan:** Sample Design

6608 W. 95th Place, Westminster, CO 80021-6422 Phone: (720) 354-8105 Fax: (720) 254-8105 Email: Joe@AuthorityAir.com Web: www.AuthorityAir.com

**Project Information**

**For:** Sample Two  
 Sample Address, Denver, CO 80000  
 Phone: (720) 354-8105 Fax: (720) 354-8105  
 Web: www.SampleWebsite.com Email: Sample@Email.com

**Notes:**

**Design Information**

**Weather:** Denver Stapleton Intl AP, CO, US

**Winter Design Conditions**

Outside db 0 °F  
 Inside db 70 °F  
 Design TD 70 °F

**Summer Design Conditions**

Outside db 91 °F  
 Inside db 75 °F  
 Design TD 16 °F  
 Daily range H  
 Relative humidity 50 %  
 Moisture difference -34 gr/lb

**Heating Summary**

Structure 52546 Btuh  
 Ducts 8885 Btuh  
 Central vent (82 cfm) 5192 Btuh  
 Humidification 5917 Btuh  
 Piping 0 Btuh  
 Equipment load 72540 Btuh

**Sensible Cooling Equipment Load Sizing**

Structure 17944 Btuh  
 Ducts 6700 Btuh  
 Central vent (82 cfm) 1172 Btuh  
 Blower 0 Btuh  
 Use manufacturer's data n  
 Rate/swing multiplier 0.96  
 Equipment sensible load 24732 Btuh

**Infiltration**

Method Simplified  
 Construction quality Tight  
 Fireplaces 1 (Tight)

	Heating	Cooling
Area (ft <sup>2</sup> )	1967	1967
Volume (ft <sup>3</sup> )	17707	17707
Air changes/hour	0.13	0.07
Equiv. AVF (cfm)	40	21

**Latent Cooling Equipment Load Sizing**

Structure -7 Btuh  
 Ducts -104 Btuh  
 Central vent (82 cfm) -1560 Btuh  
 Equipment latent load 0 Btuh  
 Equipment total load 24732 Btuh  
 Req. total capacity at 0.85 SHR 2.4 ton

**Heating Equipment Summary**

Make Carrier  
 Trade Carrier  
 Model 59SP5A100E21-20  
 AHRI ref 5285422

Efficiency 96.3 AFUE  
 Heating input 79200 MBtuh  
 Heating output 76824 Btuh  
 Temperature rise 61 °F  
 Actual air flow 1400 cfm  
 Air flow factor 0.023 cfm/Btuh  
 Static pressure 1.00 in H2O  
 Space thermostat

**Cooling Equipment Summary**

Make Carrier  
 Trade Base 13  
 Cond 24ABB336A31  
 Coil CNPHP4821A  
 AHRI ref 4741459

Efficiency 11.7 EER, 14 SEER  
 Sensible cooling 28900 Btuh  
 Latent cooling 5100 Btuh  
 Total cooling 34000 Btuh  
 Actual air flow 1400 cfm  
 Air flow factor 0.057 cfm/Btuh  
 Static pressure 1.00 in H2O  
 Load sensible heat ratio 1.00

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



**AED Assessment**  
**Entire House**  
 Authority Air Designs, LLC.

Job: Sample Address  
 Date: Oct 12, 2012  
 By: Joe Colburn  
 Plan: Sample Design

6608 W. 95th Place, Westminster, CO 80021-6422 Phone: (720) 354-8105 Fax: (720) 254-8105 Email: Joe@AuthorityAir.com Web: www.AuthorityAir.com

**Project Information**


For: Sample Two  
 Sample Address, Denver, CO 80000  
 Phone: (720) 354-8105 Fax: (720) 354-8105  
 Web: www.SampleWebsite.com Email: Sample@Email.com

**Design Conditions**

<b>Location:</b>		<b>Indoor:</b>		<b>Heating</b>	<b>Cooling</b>
Denver Stapleton Intl AP, CO, US		Indoor temperature (°F)		70	75
Elevation: 5285 ft		Design TD (°F)		70	16
Latitude: 40°N		Relative humidity (%)		50	50
		Moisture difference (gr/lb)		61.4	-34.0
<b>Outdoor:</b>	<b>Heating</b>	<b>Cooling</b>	<b>Infiltration:</b>		
Dry bulb (°F)	0	91			
Daily range (°F)	-	27 ( H )			
Wet bulb (°F)	-	60			
Wind speed (mph)	15.0	7.5			

**Test for Adequate Exposure Diversity**

Hourly Glazing Load



**Maximum hourly glazing load exceeds average by 33.1%.**

**House does not have adequate exposure diversity (AED), based on AED limit of 30%.**

**AED excursion: 846 Btuh (PFG - 1.3\*AFG)**



**AED Assessment  
Basement Zone**  
Authority Air Designs, LLC.

Job: Sample Address  
Date: Oct 12, 2012  
By: Joe Colburn  
Plan: Sample Design

6608 W. 95th Place, Westminster, CO 80021-6422 Phone: (720) 354-8105 Fax: (720) 254-8105 Email: Joe@AuthorityAir.com Web: www.AuthorityAir.com

**Project Information**


For: Sample Two  
Sample Address, Denver, CO 80000  
Phone: (720) 354-8105 Fax: (720) 354-8105  
Web: www.SampleWebsite.com Email: Sample@Email.com

**Design Conditions**

<b>Location:</b>		<b>Indoor:</b>		<b>Heating</b>	<b>Cooling</b>
Denver Stapleton Intl AP, CO, US		Indoor temperature (°F)		70	75
Elevation: 5285 ft		Design TD (°F)		70	16
Latitude: 40°N		Relative humidity (%)		50	50
		Moisture difference (gr/lb)		61.4	-34.0
<b>Outdoor:</b>	<b>Heating</b>	<b>Cooling</b>	<b>Infiltration:</b>		
Dry bulb (°F)	0	91			
Daily range (°F)	-	27 ( H )			
Wet bulb (°F)	-	60			
Wind speed (mph)	15.0	7.5			

**Test for Adequate Exposure Diversity**

Hourly Glazing Load



**Maximum hourly glazing load exceeds average by 0.0%.**

**Zone has adequate exposure diversity (AED), based on AED limit of 30%.**

**AED excursion: 0 Btuh**



# AED Assessment Conservatory Zone

Authority Air Designs, LLC.

Job: Sample Address  
Date: Oct 12, 2012  
By: Joe Colburn  
Plan: Sample Design

6608 W. 95th Place, Westminster, CO 80021-6422 Phone: (720) 354-8105 Fax: (720) 254-8105 Email: Joe@AuthorityAir.com Web: www.AuthorityAir.com

## Project Information


For: Sample Two  
Sample Address, Denver, CO 80000  
Phone: (720) 354-8105 Fax: (720) 354-8105  
Web: www.SampleWebsite.com Email: Sample@Email.com

## Design Conditions

<b>Location:</b>		<b>Indoor:</b>		<b>Heating</b>	<b>Cooling</b>
Denver Stapleton Intl AP, CO, US		Indoor temperature (°F)		70	75
Elevation: 5285 ft		Design TD (°F)		70	16
Latitude: 40°N		Relative humidity (%)		50	50
		Moisture difference (gr/lb)		61.4	-34.0
<b>Outdoor:</b>	<b>Heating</b>	<b>Cooling</b>	<b>Infiltration:</b>		
Dry bulb (°F)	0	91			
Daily range (°F)	-	27 ( H )			
Wet bulb (°F)	-	60			
Wind speed (mph)	15.0	7.5			

## Test for Adequate Exposure Diversity

Hourly Glazing Load



**Maximum hourly glazing load exceeds average by 34.1%.**

**Zone does not have adequate exposure diversity (AED), based on AED limit of 30%.**

**AED excursion: 459 Btuh (PFG - 1.3\*AFG)**





# AED Assessment Main Zone

Authority Air Designs, LLC.

Job: Sample Address  
Date: Oct 12, 2012  
By: Joe Colburn  
Plan: Sample Design

6608 W. 95th Place, Westminster, CO 80021-6422 Phone: (720) 354-8105 Fax: (720) 254-8105 Email: Joe@AuthorityAir.com Web: www.AuthorityAir.com

## Project Information


For: Sample Two  
Sample Address, Denver, CO 80000  
Phone: (720) 354-8105 Fax: (720) 354-8105  
Web: www.SampleWebsite.com Email: Sample@Email.com

## Design Conditions

<b>Location:</b>		<b>Indoor:</b>		<b>Heating</b>	<b>Cooling</b>
Denver Stapleton Intl AP, CO, US		Indoor temperature (°F)		70	75
Elevation: 5285 ft		Design TD (°F)		70	16
Latitude: 40°N		Relative humidity (%)		50	50
		Moisture difference (gr/lb)		61.4	-34.0
<b>Outdoor:</b>	<b>Heating</b>	<b>Cooling</b>	<b>Infiltration:</b>		
Dry bulb (°F)	0	91			
Daily range (°F)	-	27 ( H )			
Wet bulb (°F)	-	60			
Wind speed (mph)	15.0	7.5			

## Test for Adequate Exposure Diversity

Hourly Glazing Load



**Maximum hourly glazing load exceeds average by 40.9%.**

**Zone does not have adequate exposure diversity (AED), based on AED limit of 30%.**

**AED excursion: 909 Btuh (PFG - 1.3\*AFG)**



# AED Assessment Upper Zone Authority Air Designs, LLC.

Job: Sample Address  
Date: Oct 12, 2012  
By: Joe Colburn  
Plan: Sample Design

6608 W. 95th Place, Westminster, CO 80021-6422 Phone: (720) 354-8105 Fax: (720) 254-8105 Email: Joe@AuthorityAir.com Web: www.AuthorityAir.com

## Project Information


For: Sample Two  
Sample Address, Denver, CO 80000  
Phone: (720) 354-8105 Fax: (720) 354-8105  
Web: www.SampleWebsite.com Email: Sample@Email.com

## Design Conditions

<b>Location:</b>	Denver Stapleton Intl AP, CO, US	<b>Indoor:</b>	Indoor temperature (°F)	70	<b>Heating</b>	70	<b>Cooling</b>	75
	Elevation: 5285 ft		Design TD (°F)	70		70		16
	Latitude: 40°N		Relative humidity (%)	50		50		50
			Moisture difference (gr/lb)	61.4		61.4		-34.0
<b>Outdoor:</b>		<b>Heating</b>	<b>Cooling</b>	<b>Infiltration:</b>				
Dry bulb (°F)	0	91						
Daily range (°F)	-	27 ( H )						
Wet bulb (°F)	-	60						
Wind speed (mph)	15.0	7.5						

## Test for Adequate Exposure Diversity

Hourly Glazing Load



**Maximum hourly glazing load exceeds average by 25.7%.**

**Zone has adequate exposure diversity (AED), based on AED limit of 30%.**

**AED excursion: 0 Btuh**



# Building Analysis Entire House Authority Air Designs, LLC.

Job: Sample Address  
Date: Oct 12, 2012  
By: Joe Colburn  
Plan: Sample Design

6608 W. 95th Place, Westminster, CO 80021-6422 Phone: (720) 354-8105 Fax: (720) 254-8105 Email: Joe@AuthorityAir.com Web: www.AuthorityAir.com

## Project Information


For: Sample Two  
Sample Address, Denver, CO 80000  
Phone: (720) 354-8105 Fax: (720) 354-8105  
Web: www.SampleWebsite.com Email: Sample@Email.com

## Design Conditions

<b>Location:</b> Denver Stapleton Intl AP, CO, US Elevation: 5285 ft Latitude: 40°N	<b>Outdoor:</b> Dry bulb (°F) Daily range (°F) Wet bulb (°F) Wind speed (mph)	<b>Heating</b> 0 - - 15.0	<b>Cooling</b> 91 27 ( H ) 60 7.5	<b>Indoor:</b> Indoor temperature (°F) Design TD (°F) Relative humidity (%) Moisture difference (gr/lb)	<b>Heating</b> 70 70 50 61.4	<b>Cooling</b> 75 16 50 -34.0
				<b>Infiltration:</b> Method Construction quality Fireplaces	Simplified Tight 1 (Tight)	


## Heating

Component	Btuh/ft²	Btuh	% of load
Walls	13.2	86271	51.0
Glazing	24.1	33119	19.6
Doors	27.3	1764	1.0
Ceilings	1.9	5117	3.0
Floors	1.8	5234	3.1
Infiltration	1.2	6794	4.0
Ducts		12595	7.4
Piping		0	0
Humidification		3683	2.2
Ventilation		14741	8.7
Adjustments		0	0
<b>Total</b>		<b>169318</b>	<b>100.0</b>



## Cooling

Component	Btuh/ft²	Btuh	% of load
Walls	1.9	12361	19.7
Glazing	23.4	32129	51.3
Doors	6.3	410	0.7
Ceilings	1.3	3443	5.5
Floors	0	0	0
Infiltration	0.1	791	1.3
Ducts		8341	13.3
Ventilation		3293	5.3
Internal gains		1890	3.0
Blower		0	0
Adjustments		0	0
<b>Total</b>		<b>62658</b>	<b>100.0</b>



Latent Cooling Load = 0 Btuh  
Overall U-value = 0.141 Btuh/ft²-°F

Data entries checked.



# Building Analysis Basement Zone Authority Air Designs, LLC.

Job: Sample Address  
Date: Oct 12, 2012  
By: Joe Colburn  
Plan: Sample Design

6608 W. 95th Place, Westminster, CO 80021-6422 Phone: (720) 354-8105 Fax: (720) 254-8105 Email: Joe@AuthorityAir.com Web: www.AuthorityAir.com

## Project Information


For: Sample Two  
Sample Address, Denver, CO 80000  
Phone: (720) 354-8105 Fax: (720) 354-8105  
Web: www.SampleWebsite.com Email: Sample@Email.com

## Design Conditions

<b>Location:</b> Denver Stapleton Intl AP, CO, US Elevation: 5285 ft Latitude: 40°N	<b>Heating</b>	<b>Cooling</b>	<b>Indoor:</b> Indoor temperature (°F) Design TD (°F) Relative humidity (%) Moisture difference (gr/lb)	<b>Heating</b> 70 70 50 61.4	<b>Cooling</b> 75 16 50 -34.0
<b>Outdoor:</b> Dry bulb (°F) Daily range (°F) Wet bulb (°F) Wind speed (mph)	<b>Heating</b> 0 - - 15.0	<b>Cooling</b> 91 27 ( H ) 60 7.5	<b>Infiltration:</b> Method Construction quality Fireplaces		Simplified Tight 1 (Tight)

## Heating

Component	Btuh/ft²	Btuh	% of load
Walls	3.8	2829	70.5
Glazing	0	0	0
Doors	0	0	0
Ceilings	0	0	0
Floors	1.4	751	18.7
Infiltration	1.2	96	2.4
Ducts		0	0
Piping		0	0
Humidification		184	4.6
Ventilation		150	3.7
Adjustments		0	0
<b>Total</b>		<b>4010</b>	<b>100.0</b>



## Cooling

Component	Btuh/ft²	Btuh	% of load
Walls	0	0	0
Glazing	0	0	0
Doors	0	0	0
Ceilings	0	0	0
Floors	0	0	0
Infiltration	0	0	0
Ducts		0	0
Ventilation		0	0
Internal gains		0	0
Blower		0	0
Adjustments		0	0
<b>Total</b>		<b>0</b>	<b>0</b>

Latent Cooling Load = 0 Btuh  
Overall U-value = 0.037 Btuh/ft²-°F

WARNING: window to floor area ratio = 0.0% - less than 5%.



# Building Analysis Conservatory Zone Authority Air Designs, LLC.

Job: Sample Address  
Date: Oct 12, 2012  
By: Joe Colburn  
Plan: Sample Design

6608 W. 95th Place, Westminster, CO 80021-6422 Phone: (720) 354-8105 Fax: (720) 254-8105 Email: Joe@AuthorityAir.com Web: www.AuthorityAir.com

## Project Information

For: Sample Two  
Sample Address, Denver, CO 80000  
Phone: (720) 354-8105 Fax: (720) 354-8105  
Web: www.SampleWebsite.com Email: Sample@Email.com

## Design Conditions

### Location:

Denver Stapleton Intl AP, CO, US  
Elevation: 5285 ft  
Latitude: 40°N

### Outdoor:

Dry bulb (°F)  
Daily range (°F)  
Wet bulb (°F)  
Wind speed (mph)

### Heating

0  
-  
-  
15.0

### Cooling

91  
27 ( H )  
60  
7.5

### Indoor:

Indoor temperature (°F)  
Design TD (°F)  
Relative humidity (%)  
Moisture difference (gr/lb)

### Heating

70  
70  
50  
61.4

### Cooling

75  
16  
50  
-34.0


### Infiltration:

Method  
Construction quality  
Fireplaces

Simplified  
Tight  
1 (Tight)


## Heating

Component	Btuh/ft²	Btuh	% of load
Walls	4.5	4284	14.9
Glazing	23.3	11233	39.2
Doors	0	0	0
Ceilings	1.9	834	2.9
Floors	2.4	1383	4.8
Infiltration	1.2	1501	5.2
Ducts		3710	12.9
Piping		0	0
Humidification		3116	10.9
Ventilation		2626	9.2
Adjustments		0	0
<b>Total</b>		<b>28686</b>	<b>100.0</b>



## Cooling

Component	Btuh/ft²	Btuh	% of load
Walls	1.2	1138	6.4
Glazing	28.5	13717	76.6
Doors	0	0	0
Ceilings	1.3	561	3.1
Floors	0	0	0
Infiltration	0.1	182	1.0
Ducts		1726	9.6
Ventilation		593	3.3
Internal gains		0	0
Blower		0	0
Adjustments		0	0
<b>Total</b>		<b>17917</b>	<b>100.0</b>



Latent Cooling Load = 0 Btuh  
Overall U-value = 0.103 Btuh/ft²-°F

WARNING: window to floor area ratio = 83.0% - more than 25%.



# Building Analysis Main Zone Authority Air Designs, LLC.

Job: Sample Address  
Date: Oct 12, 2012  
By: Joe Colburn  
Plan: Sample Design

6608 W. 95th Place, Westminster, CO 80021-6422 Phone: (720) 354-8105 Fax: (720) 254-8105 Email: Joe@AuthorityAir.com Web: www.AuthorityAir.com

## Project Information


For: Sample Two  
Sample Address, Denver, CO 80000  
Phone: (720) 354-8105 Fax: (720) 354-8105  
Web: www.SampleWebsite.com Email: Sample@Email.com

## Design Conditions

<b>Location:</b> Denver Stapleton Intl AP, CO, US Elevation: 5285 ft Latitude: 40°N	<b>Outdoor:</b> Dry bulb (°F) Daily range (°F) Wet bulb (°F) Wind speed (mph)	<b>Heating</b> 0 - - 15.0	<b>Cooling</b> 91 27 ( H ) 60 7.5	<b>Indoor:</b> Indoor temperature (°F) Design TD (°F) Relative humidity (%) Moisture difference (gr/lb)	<b>Heating</b> 70 70 50 61.4	<b>Cooling</b> 75 16 50 -34.0
				<b>Infiltration:</b> Method Construction quality Fireplaces	Simplified Tight 1 (Tight)	


## Heating

Component	Btuh/ft²	Btuh	% of load
Walls	14.0	41114	53.4
Glazing	24.5	13562	17.6
Doors	27.3	1764	2.3
Ceilings	2.1	625	0.8
Floors	1.8	3100	4.0
Infiltration	1.2	2679	3.5
Ducts		0	0
Piping		0	0
Humidification		7390	9.6
Ventilation		6773	8.8
Adjustments		0	
<b>Total</b>		<b>77007</b>	<b>100.0</b>



## Cooling

Component	Btuh/ft²	Btuh	% of load
Walls	1.8	5269	27.0
Glazing	18.4	10172	52.1
Doors	6.3	410	2.1
Ceilings	1.4	421	2.2
Floors	0	0	0
Infiltration	0.1	303	1.5
Ducts		0	0
Ventilation		1529	7.8
Internal gains		1430	7.3
Blower		0	0
Adjustments		0	
<b>Total</b>		<b>19533</b>	<b>100.0</b>



Latent Cooling Load = 0 Btuh  
Overall U-value = 0.158 Btuh/ft²-°F

Data entries checked.



# Building Analysis Upper Zone Authority Air Designs, LLC.

Job: Sample Address  
Date: Oct 12, 2012  
By: Joe Colburn  
Plan: Sample Design

6608 W. 95th Place, Westminster, CO 80021-6422 Phone: (720) 354-8105 Fax: (720) 254-8105 Email: Joe@AuthorityAir.com Web: www.AuthorityAir.com

## Project Information


For: Sample Two  
Sample Address, Denver, CO 80000  
Phone: (720) 354-8105 Fax: (720) 354-8105  
Web: www.SampleWebsite.com Email: Sample@Email.com

## Design Conditions

<b>Location:</b> Denver Stapleton Intl AP, CO, US Elevation: 5285 ft Latitude: 40°N	<b>Heating</b>	<b>Cooling</b>	<b>Indoor:</b> Indoor temperature (°F) Design TD (°F) Relative humidity (%) Moisture difference (gr/lb)	<b>Heating</b> 70 70 50 61.4	<b>Cooling</b> 75 16 50 -34.0
<b>Outdoor:</b> Dry bulb (°F) Daily range (°F) Wet bulb (°F) Wind speed (mph)	0 - - 15.0	91 27 ( H ) 60 7.5	<b>Infiltration:</b> Method Construction quality Fireplaces	Simplified Tight 1 (Tight)	


## Heating

Component	Btuh/ft²	Btuh	% of load
Walls	20.5	38044	52.4
Glazing	24.5	8325	11.5
Doors	0	0	0
Ceilings	1.9	3658	5.0
Floors	0	0	0
Infiltration	1.2	2519	3.5
Ducts		8885	12.2
Piping		0	0
Humidification		5917	8.2
Ventilation		5192	7.2
Adjustments		0	0
<b>Total</b>		<b>72540</b>	<b>100.0</b>



## Cooling

Component	Btuh/ft²	Btuh	% of load
Walls	3.2	5953	23.1
Glazing	25.8	8763	33.9
Doors	0	0	0
Ceilings	1.3	2461	9.5
Floors	0	0	0
Infiltration	0.1	306	1.2
Ducts		6700	26.0
Ventilation		1172	4.5
Internal gains		460	1.8
Blower		0	0
Adjustments		0	0
<b>Total</b>		<b>25816</b>	<b>100.0</b>



Latent Cooling Load = 0 Btuh  
Overall U-value = 0.172 Btuh/ft²-°F

Data entries checked.



# Component Constructions

## Entire House

Authority Air Designs, LLC.

Job: Sample Address  
 Date: Oct 12, 2012  
 By: Joe Colburn  
 Plan: Sample Design

6608 W. 95th Place, Westminster, CO 80021-6422 Phone: (720) 354-8105 Fax: (720) 254-8105 Email: Joe@AuthorityAir.com Web: www.AuthorityAir.com

### Project Information

For: Sample Two  
 Sample Address, Denver, CO 80000  
 Phone: (720) 354-8105 Fax: (720) 354-8105  
 Web: www.SampleWebsite.com Email: Sample@Email.com

### Design Conditions

<b>Location:</b> Denver Stapleton Intl AP, CO, US Elevation: 5285 ft Latitude: 40°N	<b>Indoor:</b> Indoor temperature (°F) Design TD (°F) Relative humidity (%) Moisture difference (gr/lb)	<b>Heating</b> 70 70 50 61.4	<b>Cooling</b> 75 16 50 -34.0
<b>Outdoor:</b> Dry bulb (°F) Daily range (°F) Wet bulb (°F) Wind speed (mph)	<b>Heating</b> 0 - - 15.0	<b>Cooling</b> 91 27 ( H ) 60 7.5	<b>Infiltration:</b> Method Construction quality Fireplaces
		Simplified Tight 1 (Tight)	

### Construction descriptions

Construction descriptions	Or	Area ft²	U-value Btuh/ft²-°F	Insul R ft²-°F/Btuh	Htg HTM Btuh/ft²	Loss Btuh	Clg HTM Btuh/ft²	Gain Btuh
<b>Walls</b>								
14E-0: Blk wall, brk 4" ext, 4" thk, 1/2" gypsum board int fnsh	n	11	0.388	0	27.2	292	4.04	43
	ne	540	0.388	0	27.2	14663	4.04	2179
	se	906	0.388	0	27.2	24598	4.04	3655
	s	8	0.388	0	27.2	223	4.04	33
	sw	290	0.388	0	27.2	7874	4.04	1170
	w	11	0.388	0	27.2	292	4.04	43
	nw	686	0.388	0	27.2	18626	4.04	2767
	all	2451	0.388	0	27.2	66569	4.04	9890
15B-0c-8: Bg wall, heavy damp soil, concrete wall, 8" thk	n	24	0.117	0	8.19	193	0	0
	ne	127	0.117	0	4.09	520	0	0
	se	418	0.117	0	5.19	2171	0	0
	sw	151	0.117	0	8.19	1239	0	0
	w	24	0.117	0	8.19	193	0	0
	nw	263	0.117	0	8.19	2157	0	0
	all	1007	0.117	0	6.43	6473	0	0
12C-0bw: Frm wall, brk 4" ext, 1/2" wood shth, r-13 cav ins, 1/2" gypsum board int fnsh, 2"x4" wood frm	ne	84	0.091	13.0	6.37	532	0	0
15B13-0wc-8: Bg wall, heavy damp soil, 2"x4" wood int frm, concrete wall, r-13 cav ins, 8" thk, 1/2" gypsum board int fnsh	ne	68	0.049	13.0	3.77	257	0	0
	se	225	0.049	13.0	3.77	849	0	0
	sw	227	0.049	13.0	3.77	857	0	0
	nw	396	0.049	13.0	3.63	1435	0	0
	all	916	0.049	13.0	3.71	3399	0	0
STD - Frame - R-13 - Stucco: Stucco Ext, 1/2" Wood Shth, 2"x 4" Frm Wall, R-13 Cavity Insulation, 1/2" Gypsum Board	ne	47	0.090	13.0	6.28	297	1.67	79
STD - Frame - R-19 - Stucco: Stucco Ext, 1/2" Wood Shth, 2"x 6" Frm Wall, R-19 Cav Ins, 1/2" Gypsum Board Int Fnsh	ne	399	0.064	19.0	4.48	1789	1.19	475
	se	407	0.064	19.0	4.48	1823	1.19	485
	sw	582	0.064	19.0	4.48	2611	1.19	694
	nw	620	0.064	19.0	4.48	2778	1.19	738
	all	2007	0.064	19.0	4.48	9002	1.19	2392

### Partitions

(none)



## Windows

U-35 SHGC-22: U-35 SHGC-22 - Windows; NFRC rated (SHGC=0.22)	n	16	0.350	0	24.5	386	9.79	154	
	ne	15	0.350	0	24.5	368	19.2	288	
	ne	146	0.350	0	24.5	3571	19.2	2799	
	se	81	0.350	0	24.5	1993	22.8	1858	
	sw	9	0.350	0	24.5	221	22.8	206	
	sw	230	0.350	0	24.5	5633	22.8	5251	
	w	16	0.350	0	24.5	386	26.3	414	
	nw	39	0.350	0	24.5	943	19.2	739	
	nw	168	0.350	0	24.5	4106	19.2	3218	
	all	719	0.350	0	24.5	17605	20.8	14928	
	ne	40	0.350	0	24.5	980	0	0	
U-35 SHGC-27: U-35 SHGC-27 - Windows; NFRC rated (SHGC=0.27)	ne	42	0.350	0	24.5	1017	22.3	926	
	se	105	0.350	0	24.5	2569	26.8	2808	
	se	48	0.350	0	24.5	1184	0	0	
	s	8	0.350	0	24.5	202	16.5	137	
	sw	12	0.350	0	24.5	294	26.8	321	
	nw	48	0.350	0	24.5	1166	22.3	1062	
	all	303	0.350	0	24.5	7413	17.4	5254	
	U-35 SHGC-27 GD: U-35 SHGC-27 - Glass Door; NFRC rated (SHGC=0.27)	ne	40	0.350	0	24.5	980	0	0
		sw	21	0.350	0	24.5	523	26.8	571
		nw	70	0.350	0	24.5	1724	22.3	1570
		all	132	0.350	0	24.5	3226	16.3	2141
U-35 SHGC-22 GD: U-35 SHGC-22 - Glass Door; NFRC rated (SHGC=0.22)	sw	71	0.350	0	24.5	1731	22.8	1614	
	Skylight - U-35 SHGC-35: U-35 SHGC-35 - Skylight; NFRC rated (SHGC=0.35)	16	0.350	0	24.5	392	78.5	1256	
Skylight - U-29 SHGC-18: U-29 SHGC-18 - Skylight; NFRC rated (SHGC=0.18)	ne	48	0.290	0	20.3	974	44.1	2117	
	se	20	0.290	0	20.3	407	45.8	917	
	sw	47	0.290	0	20.3	964	45.8	2173	
	nw	20	0.290	0	20.3	407	44.1	884	
	all	136	0.290	0	20.3	2752	44.9	6091	

## Doors

11D0: Door, wd sc type	ne	18	0.390	0	27.3	488	9.20	164
	ne	20	0.390	0	27.3	549	0	0
	se	27	0.390	0	27.3	728	9.20	245
	all	65	0.390	0	27.3	1764	6.34	410

## Ceilings

STD - Attic CLG - R-30: Attic ceiling, Asphalt Shingles, R-30 Ceiling Insulation, 1/2" Gypsum Board	127	0.034	30.0	2.39	303	1.61	204
STD - Attic CLG - R-38: Attic Ceiling, Asphalt Shingles, R-38 Ceiling Insulation, 1/2" Gypsum Board	2568	0.027	38.0	1.87	4814	1.26	3239

## Floors

21A-32t: Bg floor, heavy damp soil, 8' depth	2050	0.020	0	1.40	2871	0	0
22A-tph: Bg floor, heavy damp soil, on grade depth	7	1.358	0	95.1	628	0	0
STD Floor - R-30: Framed Floor Over Outside Air, R-30 Cavity Insulation, Wood Floor	728	0.034	30.0	2.38	1735	0	0



**Component Constructions**  
**Basement Zone**  
 Authority Air Designs, LLC.

Job: Sample Address  
 Date: Oct 12, 2012  
 By: Joe Colburn  
 Plan: Sample Design

6608 W. 95th Place, Westminster, CO 80021-6422 Phone: (720) 354-8105 Fax: (720) 254-8105 Email: Joe@AuthorityAir.com Web: www.AuthorityAir.com

**Project Information**

For: Sample Two  
 Sample Address, Denver, CO 80000  
 Phone: (720) 354-8105 Fax: (720) 354-8105  
 Web: www.SampleWebsite.com Email: Sample@Email.com

**Design Conditions**

<b>Location:</b> Denver Stapleton Intl AP, CO, US Elevation: 5285 ft Latitude: 40°N	<b>Indoor:</b> Indoor temperature (°F) Design TD (°F) Relative humidity (%) Moisture difference (gr/lb)	<b>Heating</b> 70 70 50 61.4	<b>Cooling</b> 75 16 50 -34.0
<b>Outdoor:</b> Dry bulb (°F) Daily range (°F) Wet bulb (°F) Wind speed (mph)	<b>Heating</b> 0 - - 15.0	<b>Cooling</b> 91 27 ( H ) 60 7.5	<b>Infiltration:</b> Method Construction quality Fireplaces
		Simplified Tight 1 (Tight)	

**Construction descriptions**

	Or	Area ft²	U-value Btuh/ft²-°F	Insul R ft²-°F/Btuh	Htg HTM Btuh/ft²	Loss Btuh	Clg HTM Btuh/ft²	Gain Btuh
<b>Walls</b> 15B13-0wc-8: Bg wall, heavy damp soil, 2"x4" wood int frm, concrete wall, r-13 cav ins, 8" thk, 1/2" gypsum board int fnsh	ne	68	0.049	13.0	3.77	257	0	0
	se	225	0.049	13.0	3.77	849	0	0
	sw	227	0.049	13.0	3.77	857	0	0
	nw	230	0.049	13.0	3.77	866	0	0
	all	750	0.049	13.0	3.77	2829	0	0

**Partitions**  
(none)

**Windows**  
(none)

**Doors**  
(none)

**Ceilings**  
(none)

<b>Floors</b> 21A-32t: Bg floor, heavy damp soil, 8' depth		536	0.020	0	1.40	751	0	0
---	--	-----	-------	---	------	-----	---	---



# Component Constructions Conservatory Zone

Authority Air Designs, LLC.

Job: Sample Address  
Date: Oct 12, 2012  
By: Joe Colburn  
Plan: Sample Design

6608 W. 95th Place, Westminster, CO 80021-6422 Phone: (720) 354-8105 Fax: (720) 254-8105 Email: Joe@AuthorityAir.com Web: www.AuthorityAir.com

## Project Information

For: Sample Two  
Sample Address, Denver, CO 80000  
Phone: (720) 354-8105 Fax: (720) 354-8105  
Web: www.SampleWebsite.com Email: Sample@Email.com

## Design Conditions

<b>Location:</b> Denver Stapleton Intl AP, CO, US Elevation: 5285 ft Latitude: 40°N	<b>Indoor:</b> Indoor temperature (°F) Design TD (°F) Relative humidity (%) Moisture difference (gr/lb)	<b>Heating</b> 70 70 50 61.4	<b>Cooling</b> 75 16 50 -34.0
<b>Outdoor:</b> Dry bulb (°F) Daily range (°F) Wet bulb (°F) Wind speed (mph)	<b>Heating</b> 0 - - 15.0	<b>Cooling</b> 91 27 ( H ) 60 7.5	<b>Infiltration:</b> Method Construction quality Fireplaces
		Simplified Tight 1 (Tight)	

### Construction descriptions

#### Walls

STD - Frame - R-19 - Stucco: Stucco Ext, 1/2" Wood Shth, 2"x 6" Frm  
Wall, R-19 Cav Ins, 1/2" Gypsum Board Int Fnsh

	Or	Area ft²	U-value Btuh/ft²-°F	Insul R ft²-°F/Btuh	Htg HTM Btuh/ft²	Loss Btuh	Clg HTM Btuh/ft²	Gain Btuh
ne		317	0.064	19.0	4.48	1422	1.19	378
se		39	0.064	19.0	4.48	173	1.19	46
sw		332	0.064	19.0	4.48	1489	1.19	396
nw		267	0.064	19.0	4.48	1199	1.19	319
all		955	0.064	19.0	4.48	4284	1.19	1138

#### Partitions

(none)

#### Windows

U-35 SHGC-22: U-35 SHGC-22 - Windows; NFRC rated  
(SHGC=0.22)

ne		138	0.350	0	24.5	3369	19.2	2641
sw		96	0.350	0	24.5	2352	22.8	2193
nw		66	0.350	0	24.5	1617	19.2	1268
all		300	0.350	0	24.5	7338	20.4	6101

U-35 SHGC-22 GD: U-35 SHGC-22 - Glass Door; NFRC rated  
(SHGC=0.22)

sw		47	0.350	0	24.5	1143	22.8	1066
----	--	----	-------	---	------	------	------	------

Skylight - U-29 SHGC-18: U-29 SHGC-18 - Skylight; NFRC rated  
(SHGC=0.18)

ne		48	0.290	0	20.3	974	44.1	2117
se		20	0.290	0	20.3	407	45.8	917
sw		47	0.290	0	20.3	964	45.8	2173
nw		20	0.290	0	20.3	407	44.1	884
all		136	0.290	0	20.3	2752	44.9	6091

#### Doors

(none)

#### Ceilings

STD - Attic CLG - R-38: Attic Ceiling, Asphalt Shingles, R-38 Ceiling  
Insulation, 1/2" Gypsum Board

		445	0.027	38.0	1.87	834	1.26	561
--	--	-----	-------	------	------	-----	------	-----

#### Floors

STD Floor - R-30: Framed Floor Over Outside Air, R-30 Cavity  
Insulation, Wood Floor

		580	0.034	30.0	2.38	1383	0	0
--	--	-----	-------	------	------	------	---	---



wrightsoft

Uponor System Design Software 12.1.04 RSU09203

2013-Jan-02 16:43:20

Page 4

C:\Users\Joe Colburn\Documents\Downloads\Sample 2.rup Calc = MJ8 Front Door faces: N



# Component Constructions

## Main Zone

Authority Air Designs, LLC.

Job: Sample Address  
 Date: Oct 12, 2012  
 By: Joe Colburn  
 Plan: Sample Design

6608 W. 95th Place, Westminster, CO 80021-6422 Phone: (720) 354-8105 Fax: (720) 254-8105 Email: Joe@AuthorityAir.com Web: www.AuthorityAir.com

### Project Information

For: Sample Two  
 Sample Address, Denver, CO 80000  
 Phone: (720) 354-8105 Fax: (720) 354-8105  
 Web: www.SampleWebsite.com Email: Sample@Email.com

### Design Conditions

<b>Location:</b> Denver Stapleton Intl AP, CO, US Elevation: 5285 ft Latitude: 40°N	<b>Indoor:</b> Indoor temperature (°F) Design TD (°F) Relative humidity (%) Moisture difference (gr/lb)	<b>Heating</b> 70 70 50 61.4	<b>Cooling</b> 75 16 50 -34.0
<b>Outdoor:</b> Dry bulb (°F) Daily range (°F) Wet bulb (°F) Wind speed (mph)	<b>Heating</b> 0 - - 15.0	<b>Cooling</b> 91 27 ( H ) 60 7.5	<b>Infiltration:</b> Method Construction quality Fireplaces
		Simplified Tight 1 (Tight)	

### Construction descriptions

	Or	Area ft²	U-value Btuh/ft²-°F	Insul R ft²-°F/Btuh	Htg HTM Btuh/ft²	Loss Btuh	Clg HTM Btuh/ft²	Gain Btuh
<b>Walls</b>								
14E-0: Blk wall, brk 4" ext, 4" thk, 1/2" gypsum board int fnsh	n	11	0.388	0	27.2	292	4.04	43
	ne	290	0.388	0	27.2	7880	4.04	1171
	se	443	0.388	0	27.2	12041	4.04	1789
	s	8	0.388	0	27.2	223	4.04	33
	sw	140	0.388	0	27.2	3800	4.04	565
	w	11	0.388	0	27.2	292	4.04	43
	nw	242	0.388	0	27.2	6566	4.04	976
	all	1145	0.388	0	27.2	31094	4.04	4620
15B-0c-8: Bg wall, heavy damp soil, concrete wall, 8" thk	n	24	0.117	0	8.19	193	0	0
	ne	127	0.117	0	4.09	520	0	0
	se	418	0.117	0	5.19	2171	0	0
	sw	151	0.117	0	8.19	1239	0	0
	w	24	0.117	0	8.19	193	0	0
	nw	263	0.117	0	8.19	2157	0	0
	all	1007	0.117	0	6.43	6473	0	0
12C-0bw: Frm wall, brk 4" ext, 1/2" wood shth, r-13 cav ins, 1/2" gypsum board int fnsh, 2"x4" wood frm	ne	84	0.091	13.0	6.37	532	0	0
15B13-0wc-8: Bg wall, heavy damp soil, 2"x4" wood int frm, concrete wall, r-13 cav ins, 8" thk, 1/2" gypsum board int fnsh	nw	166	0.049	13.0	3.43	569	0	0
STD - Frame - R-19 - Stucco: Stucco Ext, 1/2" Wood Shth, 2"x 6" Frm Wall, R-19 Cav Ins, 1/2" Gypsum Board Int Fnsh	ne	60	0.064	19.0	4.48	269	1.19	72
	se	190	0.064	19.0	4.48	854	1.19	227
	sw	132	0.064	19.0	4.48	593	1.19	158
	nw	163	0.064	19.0	4.48	729	1.19	194
	all	545	0.064	19.0	4.48	2445	1.19	650

### Partitions

(none)

## Windows

U-35 SHGC-22: U-35 SHGC-22 - Windows; NFRC rated (SHGC=0.22)	n	16	0.350	0	24.5	386	9.79	154
	ne	15	0.350	0	24.5	368	19.2	288
	ne	8	0.350	0	24.5	202	19.2	158
	se	35	0.350	0	24.5	849	22.8	792
	sw	9	0.350	0	24.5	221	22.8	206
	sw	71	0.350	0	24.5	1742	22.8	1624
	w	16	0.350	0	24.5	386	26.3	414
	nw	39	0.350	0	24.5	943	19.2	739
	nw	67	0.350	0	24.5	1639	19.2	1285
	all	275	0.350	0	24.5	6735	20.6	5660
	U-35 SHGC-27: U-35 SHGC-27 - Windows; NFRC rated (SHGC=0.27)	ne	40	0.350	0	24.5	980	0
	ne	18	0.350	0	24.5	429	22.3	390
	se	42	0.350	0	24.5	1034	26.8	1130
	se	48	0.350	0	24.5	1184	0	0
	s	8	0.350	0	24.5	202	16.5	137
	nw	4	0.350	0	24.5	86	22.3	78
	all	160	0.350	0	24.5	3915	10.9	1735
U-35 SHGC-27 GD: U-35 SHGC-27 - Glass Door; NFRC rated (SHGC=0.27)	ne	40	0.350	0	24.5	980	0	0
	sw	21	0.350	0	24.5	523	26.8	571
	nw	34	0.350	0	24.5	821	22.3	747
	all	95	0.350	0	24.5	2323	13.9	1319
U-35 SHGC-22 GD: U-35 SHGC-22 - Glass Door; NFRC rated (SHGC=0.22)	sw	24	0.350	0	24.5	588	22.8	548

## Doors

11D0: Door, wd sc type	ne	18	0.390	0	27.3	488	9.20	164
	ne	20	0.390	0	27.3	549	0	0
	se	27	0.390	0	27.3	728	9.20	245
	all	65	0.390	0	27.3	1764	6.34	410

## Ceilings

STD - Attic CLG - R-30: Attic ceiling, Asphalt Shingles, R-30 Ceiling Insulation, 1/2" Gypsum Board	127	0.034	30.0	2.39	303	1.61	204
STD - Attic CLG - R-38: Attic Ceiling, Asphalt Shingles, R-38 Ceiling Insulation, 1/2" Gypsum Board	172	0.027	38.0	1.87	322	1.26	216

## Floors

21A-32t: Bg floor, heavy damp soil, 8' depth	1514	0.020	0	1.40	2120	0	0
22A-tph: Bg floor, heavy damp soil, on grade depth	7	1.358	0	95.1	628	0	0
STD Floor - R-30: Framed Floor Over Outside Air, R-30 Cavity Insulation, Wood Floor	148	0.034	30.0	2.38	352	0	0



# Component Constructions

## Upper Zone

Authority Air Designs, LLC.

Job: Sample Address  
 Date: Oct 12, 2012  
 By: Joe Colburn  
 Plan: Sample Design

6608 W. 95th Place, Westminster, CO 80021-6422 Phone: (720) 354-8105 Fax: (720) 254-8105 Email: Joe@AuthorityAir.com Web: www.AuthorityAir.com

### Project Information

For: Sample Two  
 Sample Address, Denver, CO 80000  
 Phone: (720) 354-8105 Fax: (720) 354-8105  
 Web: www.SampleWebsite.com Email: Sample@Email.com

### Design Conditions

<b>Location:</b> Denver Stapleton Intl AP, CO, US Elevation: 5285 ft Latitude: 40°N	<b>Indoor:</b> Indoor temperature (°F) Design TD (°F) Relative humidity (%) Moisture difference (gr/lb)	<b>Heating</b> 70 70 50 61.4	<b>Cooling</b> 75 16 50 -34.0
<b>Outdoor:</b> Dry bulb (°F) Daily range (°F) Wet bulb (°F) Wind speed (mph)	<b>Heating</b> 0 - - 15.0	<b>Cooling</b> 91 27 ( H ) 60 7.5	<b>Infiltration:</b> Method Construction quality Fireplaces
		Simplified Tight 1 (Tight)	

### Construction descriptions

	Or	Area ft²	U-value Btuh/ft²-°F	Insul R ft²-°F/Btuh	Htg HTM Btuh/ft²	Loss Btuh	Clg HTM Btuh/ft²	Gain Btuh
<b>Walls</b>								
14E-0: Blk wall, brk 4" ext, 4" thk, 1/2" gypsum board int fnsh	ne	250	0.388	0	27.2	6783	4.04	1008
	se	462	0.388	0	27.2	12557	4.04	1866
	sw	150	0.388	0	27.2	4074	4.04	605
	nw	444	0.388	0	27.2	12060	4.04	1792
	all	1306	0.388	0	27.2	35475	4.04	5271
STD - Frame - R-13 - Stucco: Stucco Ext, 1/2" Wood Shth, 2"x 4" Frm Wall, R-13 Cavity Insulation, 1/2" Gypsum Board	ne	47	0.090	13.0	6.28	297	1.67	79
STD - Frame - R-19 - Stucco: Stucco Ext, 1/2" Wood Shth, 2"x 6" Frm Wall, R-19 Cav Ins, 1/2" Gypsum Board Int Fnsh	ne	22	0.064	19.0	4.48	98	1.19	26
	se	178	0.064	19.0	4.48	796	1.19	212
	sw	118	0.064	19.0	4.48	529	1.19	141
	nw	190	0.064	19.0	4.48	850	1.19	226
	all	507	0.064	19.0	4.48	2273	1.19	604

### Partitions

(none)

### Windows

U-35 SHGC-22: U-35 SHGC-22 - Windows; NFRC rated (SHGC=0.22)	se	47	0.350	0	24.5	1143	22.8	1066
	sw	63	0.350	0	24.5	1539	22.8	1435
	nw	35	0.350	0	24.5	849	19.2	666
	all	144	0.350	0	24.5	3532	22.0	3167
U-35 SHGC-27: U-35 SHGC-27 - Windows; NFRC rated (SHGC=0.27)	ne	24	0.350	0	24.5	588	22.3	535
	se	63	0.350	0	24.5	1535	26.8	1678
	sw	12	0.350	0	24.5	294	26.8	321
	nw	44	0.350	0	24.5	1080	22.3	984
	all	143	0.350	0	24.5	3498	24.6	3519
U-35 SHGC-27 GD: U-35 SHGC-27 - Glass Door; NFRC rated (SHGC=0.27)	nw	37	0.350	0	24.5	903	22.3	822
Skylight - U-35 SHGC-35: U-35 SHGC-35 - Skylight; NFRC rated (SHGC=0.35)		16	0.350	0	24.5	392	78.5	1256

### Doors

(none)

**Ceilings**

STD - Attic CLG - R-38: Attic Ceiling, Asphalt Shingles, R-38 Ceiling  
Insulation, 1/2" Gypsum Board

1951      0.027      38.0      1.87      3658      1.26      2461

**Floors**

(none)







Right-J® Worksheet
Entire House
Authority Air Designs, LLC.

Job: Sample Address
Date: Oct 12, 2012
By: Joe Colburn
Plan: Sample Design

6608 W. 95th Place, Westminster, CO 80021-6422 Phone: (720) 354-8105 Fax: (720) 254-8105 Email: Joe@AuthorityAir.com Web: www.AuthorityAir.com

Table with columns for Room name, Ty, Construction number, U-value, Or, HTM (Heat/Cool), Area (Gross/N/P/S), Load (Heat/Cool), and Conservatory Zone (Area/Load). Rows include room details for Main Zone (8.6 ft x 413.2 ft) and Conservatory Zone (16.0 ft x 81.3 ft), and summary rows for infiltration, gains, and duct loads.

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



# Right-J® Worksheet

## Entire House

Authority Air Designs, LLC.

Job: Sample Address  
 Date: Oct 12, 2012  
 By: Joe Colburn  
 Plan: Sample Design

6608 W. 95th Place, Westminster, CO 80021-6422 Phone: (720) 354-8105 Fax: (720) 254-8105 Email: Joe@AuthorityAir.com Web: www.AuthorityAir.com

1 Room name				Upper Zone										
2 Exposed wall				242.7 ft										
3 Room height				9.0 ft										
4 Room dimensions														
5 Room area				1967.4 ft²										
	Ty	Construction number	U-value (Btuh/ft²·°F)	Or	HTM (Btuh/ft²)		Area (ft²) or perimeter (ft)		Load (Btuh)		Area or perimeter		Load	
					Heat	Cool	Gross	N/P/S	Heat	Cool	Gross	N/P/S	Heat	Cool
6	W	14E-0	0.388	n	27.16	4.04	0	0	0	0				
	G	U-35 SHGC-22	0.350	n	24.50	9.79	0	0	0	0				
	W	15B-0c-8	0.488	n	8.19	0.00	0	0	0	0				
	W	12C-0bw	0.091	ne	6.37	0.00	0	0	0	0				
11	G	U-35 SHGC-27	0.350	ne	24.50	0.00	0	0	0	0				
	G	U-35 SHGC-27 GD	0.350	ne	24.50	0.00	0	0	0	0				
	W	14E-0	0.388	ne	27.16	4.04	274	250	6783	1008				
	G	U-35 SHGC-22	0.350	ne	24.50	19.20	0	0	0	0				
	G	U-35 SHGC-27	0.350	ne	24.50	22.31	24	0	588	535				
	D	11D0	0.390	ne	27.30	9.20	0	0	0	0				
	W	15B-0c-8	0.488	ne	4.09	0.00	0	0	0	0				
	D	11D0	0.390	ne	27.30	0.00	0	0	0	0				
	W	15B13-0wc-8	0.093	ne	3.77	0.00	0	0	0	0				
	W	STD - Frame - R-13 -	0.090	ne	6.28	1.67	47	47	297	79				
	W	STD - Frame - R-19 -	0.064	ne	4.48	1.19	22	22	98	26				
	G	U-35 SHGC-22	0.350	ne	24.50	19.20	0	0	0	0				
	W	14E-0	0.388	se	27.16	4.04	525	462	12557	1866				
	G	U-35 SHGC-27	0.350	se	24.50	26.77	63	0	1535	1678				
	D	11D0	0.390	se	27.30	9.20	0	0	0	0				
	W	15B-0c-8	0.488	se	5.19	0.00	0	0	0	0				
	G	U-35 SHGC-27	0.350	se	24.50	0.00	0	0	0	0				
	W	15B13-0wc-8	0.093	se	3.77	0.00	0	0	0	0				
	W	STD - Frame - R-19 -	0.064	se	4.48	1.19	224	178	796	212				
	G	U-35 SHGC-22	0.350	se	24.50	22.84	47	0	1143	1066				
	W	14E-0	0.388	s	27.16	4.04	0	0	0	0				
	G	U-35 SHGC-27	0.350	s	24.50	16.55	0	0	0	0				
	W	14E-0	0.388	sw	27.16	4.04	162	150	4074	605				
	G	U-35 SHGC-22	0.350	sw	24.50	22.84	0	0	0	0				
	G	U-35 SHGC-27	0.350	sw	24.50	26.77	12	0	294	321				
	G	U-35 SHGC-27 GD	0.350	sw	24.50	26.77	0	0	0	0				
	W	15B-0c-8	0.488	sw	8.19	0.00	0	0	0	0				
	W	15B13-0wc-8	0.093	sw	3.77	0.00	0	0	0	0				
	W	STD - Frame - R-19 -	0.064	sw	4.48	1.19	181	118	529	141				
	G	U-35 SHGC-22	0.350	sw	24.50	22.84	63	0	1539	1435				
	G	U-35 SHGC-22 GD	0.350	sw	24.50	22.84	0	0	0	0				
	W	14E-0	0.388	w	27.16	4.04	0	0	0	0				
	G	U-35 SHGC-22	0.350	w	24.50	26.30	0	0	0	0				
	W	15B-0c-8	0.488	w	8.19	0.00	0	0	0	0				
	W	14E-0	0.388	nw	27.16	4.04	525	444	12060	1792				
	G	U-35 SHGC-22	0.350	nw	24.50	19.20	0	0	0	0				
	G	U-35 SHGC-27	0.350	nw	24.50	22.31	44	0	1080	984				
	G	U-35 SHGC-27 GD	0.350	nw	24.50	22.31	37	0	903	822				
	W	15B-0c-8	0.488	nw	8.19	0.00	0	0	0	0				
	W	15B13-0wc-8	0.093	nw	3.63	0.00	0	0	0	0				
	W	STD - Frame - R-19 -	0.064	nw	4.48	1.19	224	190	850	226				
	G	U-35 SHGC-22	0.350	nw	24.50	19.20	35	0	849	666				
	C	STD - Attic CLG - R-	0.034	-	2.39	1.61	0	0	0	0				
	C	STD - Attic CLG - R-	0.027	-	1.87	1.26	1967	1951	3658	2461				
	G	Skylight - U-35 SHGC	0.350	-	24.50	78.50	16	0	392	1256				
	G	Skylight - U-29 SHGC	0.290	ne	20.30	44.11	0	0	0	0				
6	c) AED excursion								0					
	Envelope loss/gain								50027		17178			
12	a) Infiltration								2519		306			
	b) Room ventilation								0		0			
13	Internal gains:		Occupants @ Appliances/other		230		2		460		0			
	Subtotal (lines 6 to 13)								52546		17944			
	Less external load								0		0			
	Less transfer								0		0			
	Redistribution								0		0			
14	Subtotal								52546		17944			
15	Duct loads						17%		37%		8885		6700	
	Total room load								61431		24644			
	Air required (cfm)								1400		1400			

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



# Right-J® Worksheet Basement Zone Authority Air Designs, LLC.

Job: Sample Address  
Date: Oct 12, 2012  
By: Joe Colburn  
Plan: Sample Design

6608 W. 95th Place, Westminster, CO 80021-6422 Phone: (720) 354-8105 Fax: (720) 254-8105 Email: Joe@AuthorityAir.com Web: www.AuthorityAir.com

		Basement Zone						Dn Library						
1	Room name	83.3 ft						48.3 ft						
2	Exposed wall	9.0 ft						9.0 ft						
3	Room height	d						heat only						
4	Room dimensions							1.0 x 385.4 ft						
5	Room area	536.4 ft²						385.4 ft²						
	Ty	Construction number	U-value (Btuh/ft²·°F)	Or	HTM (Btuh/ft²)		Area (ft²) or perimeter (ft)		Load (Btuh)		Area (ft²) or perimeter (ft)		Load (Btuh)	
					Heat	Cool	Gross	N/P/S	Heat	Cool	Gross	N/P/S	Heat	Cool
6	W	14E-0	0.388	n	0.00	0.00	0	0	0	0	0	0	0	0
	G	U-35 SHGC-22	0.350	n	0.00	0.00	0	0	0	0	0	0	0	0
	W	15B-0c-8	0.488	n	0.00	0.00	0	0	0	0	0	0	0	0
	W	12C-0bw	0.091	ne	0.00	0.00	0	0	0	0	0	0	0	0
11	G	U-35 SHGC-27	0.350	ne	0.00	0.00	0	0	0	0	0	0	0	0
	G	U-35 SHGC-27 GD	0.350	ne	0.00	0.00	0	0	0	0	0	0	0	0
	W	14E-0	0.388	ne	0.00	0.00	0	0	0	0	0	0	0	0
	G	U-35 SHGC-22	0.350	ne	0.00	0.00	0	0	0	0	0	0	0	0
	G	U-35 SHGC-27	0.350	ne	0.00	0.00	0	0	0	0	0	0	0	0
	D	11D0	0.390	ne	0.00	0.00	0	0	0	0	0	0	0	0
	W	15B-0c-8	0.488	ne	0.00	0.00	0	0	0	0	0	0	0	0
	D	11D0	0.390	ne	0.00	0.00	0	0	0	0	0	0	0	0
	W	15B13-0wc-8	0.093	ne	3.77	0.00	68	68	257	0	0	0	0	0
	W	STD - Frame - R-13 -	0.090	ne	0.00	0.00	0	0	0	0	0	0	0	0
	W	STD - Frame - R-19 -	0.064	ne	0.00	0.00	0	0	0	0	0	0	0	0
	G	U-35 SHGC-22	0.350	ne	0.00	0.00	0	0	0	0	0	0	0	0
	W	14E-0	0.388	se	0.00	0.00	0	0	0	0	0	0	0	0
	G	U-35 SHGC-27	0.350	se	0.00	0.00	0	0	0	0	0	0	0	0
	D	11D0	0.390	se	0.00	0.00	0	0	0	0	0	0	0	0
	W	15B-0c-8	0.488	se	0.00	0.00	0	0	0	0	0	0	0	0
	G	U-35 SHGC-27	0.350	se	0.00	0.00	0	0	0	0	0	0	0	0
	W	15B13-0wc-8	0.093	se	3.77	0.00	225	225	849	0	225	225	849	0
	W	STD - Frame - R-19 -	0.064	se	0.00	0.00	0	0	0	0	0	0	0	0
	G	U-35 SHGC-22	0.350	se	0.00	0.00	0	0	0	0	0	0	0	0
	W	14E-0	0.388	s	0.00	0.00	0	0	0	0	0	0	0	0
	G	U-35 SHGC-27	0.350	s	0.00	0.00	0	0	0	0	0	0	0	0
	W	14E-0	0.388	sw	0.00	0.00	0	0	0	0	0	0	0	0
	G	U-35 SHGC-22	0.350	sw	0.00	0.00	0	0	0	0	0	0	0	0
	G	U-35 SHGC-27	0.350	sw	0.00	0.00	0	0	0	0	0	0	0	0
	G	U-35 SHGC-27 GD	0.350	sw	0.00	0.00	0	0	0	0	0	0	0	0
	W	15B-0c-8	0.488	sw	0.00	0.00	0	0	0	0	0	0	0	0
	W	15B13-0wc-8	0.093	sw	3.77	0.00	227	227	857	0	147	147	555	0
	W	STD - Frame - R-19 -	0.064	sw	0.00	0.00	0	0	0	0	0	0	0	0
	G	U-35 SHGC-22	0.350	sw	0.00	0.00	0	0	0	0	0	0	0	0
	G	U-35 SHGC-22 GD	0.350	sw	0.00	0.00	0	0	0	0	0	0	0	0
	W	14E-0	0.388	w	0.00	0.00	0	0	0	0	0	0	0	0
	G	U-35 SHGC-22	0.350	w	0.00	0.00	0	0	0	0	0	0	0	0
	W	15B-0c-8	0.488	w	0.00	0.00	0	0	0	0	0	0	0	0
	W	14E-0	0.388	nw	0.00	0.00	0	0	0	0	0	0	0	0
	G	U-35 SHGC-22	0.350	nw	0.00	0.00	0	0	0	0	0	0	0	0
	G	U-35 SHGC-27	0.350	nw	0.00	0.00	0	0	0	0	0	0	0	0
	G	U-35 SHGC-27 GD	0.350	nw	0.00	0.00	0	0	0	0	0	0	0	0
	W	15B-0c-8	0.488	nw	0.00	0.00	0	0	0	0	0	0	0	0
	W	15B13-0wc-8	0.093	nw	3.77	0.00	230	230	866	0	62	62	235	0
	W	STD - Frame - R-19 -	0.064	nw	0.00	0.00	0	0	0	0	0	0	0	0
	G	U-35 SHGC-22	0.350	nw	0.00	0.00	0	0	0	0	0	0	0	0
	C	STD - Attic CLG - R-	0.034	-	0.00	0.00	0	0	0	0	0	0	0	0
	C	STD - Attic CLG - R-	0.027	-	0.00	0.00	0	0	0	0	0	0	0	0
	G	Skylight - U-35 SHGC	0.350	-	0.00	0.00	0	0	0	0	0	0	0	0
	G	Skylight - U-29 SHGC	0.290	ne	0.00	0.00	0	0	0	0	0	0	0	0
6	c) AED excursion								0					0
	Envelope loss/gain								3580	0				2178
12	a) Infiltration								96	0				56
	b) Room ventilation								0	0				0
13	Internal gains:		Occupants @	230			0		0	0				0
			Appliances/other						0	0				0
	Subtotal (lines 6 to 13)								3676	0				2233
	Less external load								0	0				0
	Less transfer								0	0				0
	Redistribution								0	0				0
14	Subtotal								3676	0				2233
15	Duct loads						0%	0%	0	0	-0%	0%		0
	Total room load								3676	0				2233
	Air required (cfm)								43	0				26

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.













# Right-J® Worksheet

## Main Zone

Authority Air Designs, LLC.

Job: Sample Address  
 Date: Oct 12, 2012  
 By: Joe Colburn  
 Plan: Sample Design

6608 W. 95th Place, Westminster, CO 80021-6422 Phone: (720) 354-8105 Fax: (720) 254-8105 Email: Joe@AuthorityAir.com Web: www.AuthorityAir.com

		Powder		K Entry										
1	Room name	9.0 ft		9.0 ft										
2	Exposed wall	9.3 ft		16.6 ft										
3	Room height	heat/cool		heat/cool										
4	Room dimensions	1.0 x 49.9 ft		9.2 x 8.3 ft										
5	Room area	49.9 ft²		76.4 ft²										
	Ty	Construction number	U-value (Btuh/ft²·°F)	Or	HTM (Btuh/ft²)		Area (ft²) or perimeter (ft)		Load (Btuh)		Area (ft²) or perimeter (ft)		Load (Btuh)	
					Heat	Cool	Gross	N/P/S	Heat	Cool	Gross	N/P/S	Heat	Cool
6	W	14E-0	0.388	n	27.16	4.04	0	0	0	0	0	0	0	0
	G	U-35 SHGC-22	0.350	n	24.50	9.79	0	0	0	0	0	0	0	0
	W	15B-0c-8	0.488	n	8.19	0.00	0	0	0	0	0	0	0	0
	W	12C-0bw	0.091	ne	6.37	0.00	0	0	0	0	0	0	0	0
11	G	U-35 SHGC-27	0.350	ne	24.50	0.00	0	0	0	0	0	0	0	0
	G	U-35 SHGC-27 GD	0.350	ne	24.50	0.00	0	0	0	0	0	0	0	0
	W	14E-0	0.388	ne	27.16	4.04	32	32	856	127	75	57	1552	231
	G	U-35 SHGC-22	0.350	ne	24.50	19.20	0	0	0	0	0	0	0	0
	G	U-35 SHGC-27	0.350	ne	24.50	22.31	0	0	0	0	0	0	0	0
	D	11D0	0.390	ne	27.30	9.20	0	0	0	0	18	18	488	164
	W	15B-0c-8	0.488	ne	4.09	0.00	0	0	0	0	0	0	0	0
	D	11D0	0.390	ne	27.30	0.00	0	0	0	0	0	0	0	0
	W	15B13-0wc-8	0.093	ne	0.00	0.00	0	0	0	0	0	0	0	0
	W	STD - Frame - R-13 -	0.090	ne	0.00	0.00	0	0	0	0	0	0	0	0
	W	STD - Frame - R-19 -	0.064	ne	4.48	1.19	0	0	0	0	0	0	0	0
	G	U-35 SHGC-22	0.350	ne	24.50	19.20	0	0	0	0	0	0	0	0
	W	14E-0	0.388	se	27.16	4.04	52	52	1406	209	74	68	1854	275
	G	U-35 SHGC-27	0.350	se	24.50	26.77	0	0	0	0	6	0	147	161
	D	11D0	0.390	se	27.30	9.20	0	0	0	0	0	0	0	0
	W	15B-0c-8	0.488	se	5.19	0.00	0	0	0	0	0	0	0	0
	G	U-35 SHGC-27	0.350	se	24.50	0.00	0	0	0	0	0	0	0	0
	W	15B13-0wc-8	0.093	se	0.00	0.00	0	0	0	0	0	0	0	0
	W	STD - Frame - R-19 -	0.064	se	4.48	1.19	0	0	0	0	0	0	0	0
	G	U-35 SHGC-22	0.350	se	24.50	22.84	0	0	0	0	0	0	0	0
	W	14E-0	0.388	s	27.16	4.04	0	0	0	0	0	0	0	0
	G	U-35 SHGC-27	0.350	s	24.50	16.55	0	0	0	0	0	0	0	0
	W	14E-0	0.388	sw	27.16	4.04	0	0	0	0	0	0	0	0
	G	U-35 SHGC-22	0.350	sw	24.50	22.84	0	0	0	0	0	0	0	0
	G	U-35 SHGC-27	0.350	sw	0.00	0.00	0	0	0	0	0	0	0	0
	G	U-35 SHGC-27 GD	0.350	sw	24.50	26.77	0	0	0	0	0	0	0	0
	W	15B-0c-8	0.488	sw	8.19	0.00	0	0	0	0	0	0	0	0
	W	15B13-0wc-8	0.093	sw	0.00	0.00	0	0	0	0	0	0	0	0
	W	STD - Frame - R-19 -	0.064	sw	4.48	1.19	0	0	0	0	0	0	0	0
	G	U-35 SHGC-22	0.350	sw	24.50	22.84	0	0	0	0	0	0	0	0
	G	U-35 SHGC-22 GD	0.350	sw	24.50	22.84	0	0	0	0	0	0	0	0
	W	14E-0	0.388	w	27.16	4.04	0	0	0	0	0	0	0	0
	G	U-35 SHGC-22	0.350	w	24.50	26.30	0	0	0	0	0	0	0	0
	W	15B-0c-8	0.488	w	8.19	0.00	0	0	0	0	0	0	0	0
	W	14E-0	0.388	nw	27.16	4.04	0	0	0	0	0	0	0	0
	G	U-35 SHGC-22	0.350	nw	24.50	19.20	0	0	0	0	0	0	0	0
	G	U-35 SHGC-27	0.350	nw	24.50	22.31	0	0	0	0	0	0	0	0
	G	U-35 SHGC-27 GD	0.350	nw	24.50	22.31	0	0	0	0	0	0	0	0
	W	15B-0c-8	0.488	nw	8.19	0.00	0	0	0	0	0	0	0	0
	W	15B13-0wc-8	0.093	nw	3.43	0.00	0	0	0	0	0	0	0	0
	W	STD - Frame - R-19 -	0.064	nw	4.48	1.19	0	0	0	0	0	0	0	0
	G	U-35 SHGC-22	0.350	nw	24.50	19.20	0	0	0	0	0	0	0	0
	C	STD - Attic CLG - R-	0.034	-	2.39	1.61	0	0	0	0	0	0	0	0
	C	STD - Attic CLG - R-	0.027	-	1.87	1.26	1	1	2	1	45	45	84	56
	G	Skylight - U-35 SHGC	0.350	-	0.00	0.00	0	0	0	0	0	0	0	0
	G	Skylight - U-29 SHGC	0.290	ne	0.00	0.00	0	0	0	0	0	0	0	0
6	c) AED excursion												-16	
	Envelope loss/gain								2263		324		871	
12	a) Infiltration								96		12		21	
	b) Room ventilation								0		0		0	
13	Internal gains:		Occupants @ 230				0		0		0		0	
			Appliances/other						0		0		0	
	Subtotal (lines 6 to 13)								2359		336		892	
	Less external load								0		0		0	
	Less transfer								0		0		0	
	Redistribution								0		0		0	
14	Subtotal								2359		336		892	
15	Duct loads						-0%		0%		-0%		0%	
	Total room load								2359		336		892	
	Air required (cfm)								53		26		96	

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.







**Right-J® Worksheet**  
**Main Zone**  
 Authority Air Designs, LLC.

**Job:** Sample Address  
**Date:** Oct 12, 2012  
**By:** Joe Colburn  
**Plan:** Sample Design

6608 W. 95th Place, Westminster, CO 80021-6422 Phone: (720) 354-8105 Fax: (720) 254-8105 Email: Joe@AuthorityAir.com Web: www.AuthorityAir.com

					Pantry 2.3 ft heat/cool 9.0 ft 1.0 x 34.1 ft 34.1 ft²				Nook 6.6 ft heat/cool 9.0 ft 14.1 x 6.6 ft 92.7 ft²												
	Ty	Construction number	U-value (Btuh/ft²-°F)	Or	HTM (Btuh/ft²)		Area (ft²) or perimeter (ft)		Load (Btuh)		Area (ft²) or perimeter (ft)		Load (Btuh)								
					Heat	Cool	Gross	N/P/S	Heat	Cool	Gross	N/P/S	Heat	Cool							
6	W	14E-0	0.388	n	27.16	4.04	0	0	0	0	0	0	0	0							
	G	U-35 SHGC-22	0.350	n	24.50	9.79	0	0	0	0	0	0	0	0							
	W	15B-0c-8	0.488	n	8.19	0.00	0	0	0	0	0	0	0	0							
	W	12C-0bw	0.091	ne	6.37	0.00	0	0	0	0	0	0	0	0							
11	G	U-35 SHGC-27	0.350	ne	24.50	0.00	0	0	0	0	0	0	0	0							
	G	U-35 SHGC-27 GD	0.350	ne	24.50	0.00	0	0	0	0	0	0	0	0							
	W	14E-0	0.388	ne	27.16	4.04	0	0	0	0	59	44	1202	179							
	G	U-35 SHGC-22	0.350	ne	24.50	19.20	0	0	0	0	15	0	368	288							
	G	U-35 SHGC-27	0.350	ne	24.50	22.31	0	0	0	0	0	0	0	0							
	D	11D0	0.390	ne	27.30	9.20	0	0	0	0	0	0	0	0							
	W	15B-0c-8	0.488	ne	4.09	0.00	0	0	0	0	0	0	0	0							
	D	11D0	0.390	ne	27.30	0.00	0	0	0	0	0	0	0	0							
	W	15B13-0wc-8	0.093	ne	0.00	0.00	0	0	0	0	0	0	0	0							
	W	STD - Frame - R-13 -	0.090	ne	0.00	0.00	0	0	0	0	0	0	0	0							
	W	STD - Frame - R-19 -	0.064	ne	4.48	1.19	0	0	0	0	0	0	0	0							
	G	U-35 SHGC-22	0.350	ne	24.50	19.20	0	0	0	0	0	0	0	0							
	W	14E-0	0.388	se	27.16	4.04	0	0	0	0	0	0	0	0							
	G	U-35 SHGC-27	0.350	se	24.50	26.77	0	0	0	0	0	0	0	0							
	D	11D0	0.390	se	27.30	9.20	0	0	0	0	0	0	0	0							
	W	15B-0c-8	0.488	se	5.19	0.00	0	0	0	0	0	0	0	0							
	G	U-35 SHGC-27	0.350	se	24.50	0.00	0	0	0	0	0	0	0	0							
	W	15B13-0wc-8	0.093	se	0.00	0.00	0	0	0	0	0	0	0	0							
	W	STD - Frame - R-19 -	0.064	se	4.48	1.19	0	0	0	0	0	0	0	0							
	G	U-35 SHGC-22	0.350	se	24.50	22.84	0	0	0	0	0	0	0	0							
	W	14E-0	0.388	s	27.16	4.04	0	0	0	0	0	0	0	0							
	G	U-35 SHGC-27	0.350	s	24.50	16.55	0	0	0	0	0	0	0	0							
	W	14E-0	0.388	sw	27.16	4.04	0	0	0	0	0	0	0	0							
	G	U-35 SHGC-22	0.350	sw	24.50	22.84	0	0	0	0	0	0	0	0							
	G	U-35 SHGC-27	0.350	sw	0.00	0.00	0	0	0	0	0	0	0	0							
	G	U-35 SHGC-27 GD	0.350	sw	24.50	26.77	0	0	0	0	0	0	0	0							
	W	15B-0c-8	0.488	sw	8.19	0.00	0	0	0	0	0	0	0	0							
	W	15B13-0wc-8	0.093	sw	0.00	0.00	0	0	0	0	0	0	0	0							
	W	STD - Frame - R-19 -	0.064	sw	4.48	1.19	0	0	0	0	0	0	0	0							
	G	U-35 SHGC-22	0.350	sw	24.50	22.84	0	0	0	0	0	0	0	0							
	G	U-35 SHGC-22 GD	0.350	sw	24.50	22.84	0	0	0	0	0	0	0	0							
	W	14E-0	0.388	w	27.16	4.04	0	0	0	0	0	0	0	0							
	G	U-35 SHGC-22	0.350	w	24.50	26.30	0	0	0	0	0	0	0	0							
	W	15B-0c-8	0.488	w	8.19	0.00	0	0	0	0	0	0	0	0							
	W	14E-0	0.388	nw	27.16	4.04	21	18	475	71	0	0	0	0							
	G	U-35 SHGC-22	0.350	nw	24.50	19.20	0	0	0	0	0	0	0	0							
	G	U-35 SHGC-27	0.350	nw	24.50	22.31	4	0	86	78	0	0	0	0							
	G	U-35 SHGC-27 GD	0.350	nw	24.50	22.31	0	0	0	0	0	0	0	0							
	W	15B-0c-8	0.488	nw	8.19	0.00	0	0	0	0	0	0	0	0							
	W	15B13-0wc-8	0.093	nw	3.43	0.00	0	0	0	0	0	0	0	0							
	W	STD - Frame - R-19 -	0.064	nw	4.48	1.19	0	0	0	0	0	0	0	0							
	G	U-35 SHGC-22	0.350	nw	24.50	19.20	0	0	0	0	0	0	0	0							
	C	STD - Attic CLG - R-	0.034	-	2.39	1.61	34	34	81	55	93	93	222	149							
	C	STD - Attic CLG - R-	0.027	-	1.87	1.26	0	0	0	0	0	0	0	0							
	G	Skylight - U-35 SHGC	0.350	-	0.00	0.00	0	0	0	0	0	0	0	0							
	G	Skylight - U-29 SHGC	0.290	ne	0.00	0.00	0	0	0	0	0	0	0	0							
6	c) AED excursion													-23							
Envelope loss/gain									724	226					2012	593					
12	a) Infiltration													24	3					68	8
	b) Room ventilation													0	0					0	0
13	Internal gains: Occupants @ 230													0	0					0	0
	Appliances/other													0	0					0	0
Subtotal (lines 6 to 13)									748	229					2080	601					
Less external load									0	0					0	0					
Less transfer									0	0					0	0					
Redistribution									0	0					0	0					
14	Subtotal													748	229					2080	601
15	Duct loads													-0%	0%					0	0
Total room load									748	229					2080	601					
Air required (cfm)									17	18					46	47					

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.









# Right-J® Worksheet Upper Zone Authority Air Designs, LLC.

Job: Sample Address  
Date: Oct 12, 2012  
By: Joe Colburn  
Plan: Sample Design

6608 W. 95th Place, Westminster, CO 80021-6422 Phone: (720) 354-8105 Fax: (720) 254-8105 Email: Joe@AuthorityAir.com Web: www.AuthorityAir.com

1 Room name				Upper Zone 242.7 ft <sup>2</sup>				Dressing 72.3 ft <sup>2</sup>							
2 Exposed wall				9.0 ft				9.0 ft							
3 Room height				d				1.0 x 441.2 ft							
4 Room dimensions				1967.4 ft <sup>2</sup>				441.2 ft <sup>2</sup>							
5 Room area															
6	Ty	Construction number	U-value (Btuh/ft <sup>2</sup> -°F)	Or	HTM (Btuh/ft <sup>2</sup> )		Area (ft <sup>2</sup> ) or perimeter (ft)		Load (Btuh)		Area (ft <sup>2</sup> ) or perimeter (ft)		Load (Btuh)		
					Heat	Cool	Gross	N/P/S	Heat	Cool	Gross	N/P/S	Heat	Cool	
6	W	14E-0	0.388	n	0.00	0.00	0	0	0	0	0	0	0	0	
	G	U-35 SHGC-22	0.350	n	0.00	0.00	0	0	0	0	0	0	0	0	
	W	15B-0c-8	0.488	n	0.00	0.00	0	0	0	0	0	0	0	0	
	W	12C-0bw	0.091	ne	0.00	0.00	0	0	0	0	0	0	0	0	
11	G	U-35 SHGC-27	0.350	ne	0.00	0.00	0	0	0	0	0	0	0	0	
	G	U-35 SHGC-27 GD	0.350	ne	0.00	0.00	0	0	0	0	0	0	0	0	
	W	14E-0	0.388	ne	27.16	4.04	274	250	6783	1008	0	0	0	0	
	G	U-35 SHGC-22	0.350	ne	0.00	0.00	0	0	0	0	0	0	0	0	
	G	U-35 SHGC-27	0.350	ne	24.50	22.31	24	0	588	535	0	0	0	0	
	D	11D0	0.390	ne	0.00	0.00	0	0	0	0	0	0	0	0	
	W	15B-0c-8	0.488	ne	0.00	0.00	0	0	0	0	0	0	0	0	
	D	11D0	0.390	ne	0.00	0.00	0	0	0	0	0	0	0	0	
	W	15B13-0wc-8	0.093	ne	0.00	0.00	0	0	0	0	0	0	0	0	
	W	STD - Frame - R-13 -	0.090	ne	6.28	1.67	47	47	297	79	0	0	0	0	
	W	STD - Frame - R-19 -	0.064	ne	4.48	1.19	22	22	98	26	22	22	98	26	
	G	U-35 SHGC-22	0.350	ne	0.00	0.00	0	0	0	0	0	0	0	0	
	W	14E-0	0.388	se	27.16	4.04	525	462	12557	1866	0	0	0	0	
	G	U-35 SHGC-27	0.350	se	24.50	26.77	63	0	1535	1678	0	0	0	0	
	D	11D0	0.390	se	0.00	0.00	0	0	0	0	0	0	0	0	
	W	15B-0c-8	0.488	se	0.00	0.00	0	0	0	0	0	0	0	0	
	G	U-35 SHGC-27	0.350	se	0.00	0.00	0	0	0	0	0	0	0	0	
	W	15B13-0wc-8	0.093	se	0.00	0.00	0	0	0	0	0	0	0	0	
	W	STD - Frame - R-19 -	0.064	se	4.48	1.19	224	178	796	212	224	178	796	212	
	G	U-35 SHGC-22	0.350	se	24.50	22.84	47	0	1143	1066	47	0	1143	1066	
	W	14E-0	0.388	s	0.00	0.00	0	0	0	0	0	0	0	0	
	G	U-35 SHGC-27	0.350	s	0.00	0.00	0	0	0	0	0	0	0	0	
	W	14E-0	0.388	sw	27.16	4.04	162	150	4074	605	0	0	0	0	
	G	U-35 SHGC-22	0.350	sw	0.00	0.00	0	0	0	0	0	0	0	0	
	G	U-35 SHGC-27	0.350	sw	24.50	26.77	12	0	294	321	0	0	0	0	
	G	U-35 SHGC-27 GD	0.350	sw	0.00	0.00	0	0	0	0	0	0	0	0	
	W	15B-0c-8	0.488	sw	0.00	0.00	0	0	0	0	0	0	0	0	
	W	15B13-0wc-8	0.093	sw	0.00	0.00	0	0	0	0	0	0	0	0	
	W	STD - Frame - R-19 -	0.064	sw	4.48	1.19	181	118	529	141	181	118	529	141	
	G	U-35 SHGC-22	0.350	sw	24.50	22.84	63	0	1539	1435	63	0	1539	1435	
	G	U-35 SHGC-22 GD	0.350	sw	0.00	0.00	0	0	0	0	0	0	0	0	
	W	14E-0	0.388	w	0.00	0.00	0	0	0	0	0	0	0	0	
	G	U-35 SHGC-22	0.350	w	0.00	0.00	0	0	0	0	0	0	0	0	
	W	15B-0c-8	0.488	w	0.00	0.00	0	0	0	0	0	0	0	0	
	W	14E-0	0.388	nw	27.16	4.04	525	444	12060	1792	0	0	0	0	
	G	U-35 SHGC-22	0.350	nw	0.00	0.00	0	0	0	0	0	0	0	0	
	G	U-35 SHGC-27	0.350	nw	24.50	22.31	44	0	1080	984	0	0	0	0	
	G	U-35 SHGC-27 GD	0.350	nw	24.50	22.31	37	0	903	822	0	0	0	0	
	W	15B-0c-8	0.488	nw	0.00	0.00	0	0	0	0	0	0	0	0	
	W	15B13-0wc-8	0.093	nw	0.00	0.00	0	0	0	0	0	0	0	0	
	W	STD - Frame - R-19 -	0.064	nw	4.48	1.19	224	190	850	226	224	190	850	226	
	G	U-35 SHGC-22	0.350	nw	24.50	19.20	35	0	849	666	35	0	849	666	
	C	STD - Attic CLG - R-	0.034	-	0.00	0.00	0	0	0	0	0	0	0	0	
	C	STD - Attic CLG - R-	0.027	-	1.87	1.26	1967	1951	3658	2461	441	441	827	557	
	G	Skylight - U-35 SHGC	0.350	-	24.50	78.50	16	0	392	1256	0	0	0	0	
	G	Skylight - U-29 SHGC	0.290	ne	0.00	0.00	0	0	0	0	0	0	0	0	
6	c) AED excursion													41	
Envelope loss/gain									50027	17178			6632	4369	
12	a) Infiltration									2519	306			751	91
	b) Room ventilation									0	0			0	0
13	Internal gains:			Occupants @	230	2				460	0			0	0
				Appliances/other						0				0	0
Subtotal (lines 6 to 13)									52546	17944			7383	4460	
Less external load									0	0			0	0	
Less transfer									0	0			0	0	
Redistribution									0	0			0	0	
14	Subtotal									52546	17944			7383	4460
15	Duct loads					17%		37%		8885	6700	17%		1248	1665
Total room load									61431	24644			8631	6125	
Air required (cfm)									1400	1400			197	348	

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.





# Right-J® Worksheet Upper Zone Authority Air Designs, LLC.

Job: Sample Address  
Date: Oct 12, 2012  
By: Joe Colburn  
Plan: Sample Design

6608 W. 95th Place, Westminster, CO 80021-6422 Phone: (720) 354-8105 Fax: (720) 254-8105 Email: Joe@AuthorityAir.com Web: www.AuthorityAir.com

		Hall 16.3 ft heat/cool						Bath 2 5.3 ft heat/cool						
		9.0 ft 1.0 x 195.6 ft 195.6 ft²			9.0 ft 5.1 x 8.3 ft 42.4 ft²									
	Ty	Construction number	U-value (Btuh/ft²·°F)	Or	HTM (Btuh/ft²)		Area (ft²) or perimeter (ft)		Load (Btuh)		Area (ft²) or perimeter (ft)		Load (Btuh)	
					Heat	Cool	Gross	N/P/S	Heat	Cool	Gross	N/P/S	Heat	Cool
6	W	14E-0	0.388	n	0.00	0.00	0	0	0	0	0	0	0	0
	└G	U-35 SHGC-22	0.350	n	0.00	0.00	0	0	0	0	0	0	0	0
	W	15B-0c-8	0.488	n	0.00	0.00	0	0	0	0	0	0	0	0
	└W	12C-0bw	0.091	ne	0.00	0.00	0	0	0	0	0	0	0	0
11	└G	U-35 SHGC-27	0.350	ne	0.00	0.00	0	0	0	0	0	0	0	0
	└G	U-35 SHGC-27 GD	0.350	ne	0.00	0.00	0	0	0	0	0	0	0	0
	W	14E-0	0.388	ne	27.16	4.04	32	32	856	127	0	0	0	0
	└G	U-35 SHGC-22	0.350	ne	0.00	0.00	0	0	0	0	0	0	0	0
	└G	U-35 SHGC-27	0.350	ne	24.50	22.31	0	0	0	0	0	0	0	0
	└D	11D0	0.390	ne	0.00	0.00	0	0	0	0	0	0	0	0
	W	15B-0c-8	0.488	ne	0.00	0.00	0	0	0	0	0	0	0	0
	└D	11D0	0.390	ne	0.00	0.00	0	0	0	0	0	0	0	0
	W	15B13-0wc-8	0.093	ne	0.00	0.00	0	0	0	0	0	0	0	0
	W	STD - Frame - R-13 -	0.090	ne	6.28	1.67	0	0	0	0	47	47	297	79
	└W	STD - Frame - R-19 -	0.064	ne	4.48	1.19	0	0	0	0	0	0	0	0
	└G	U-35 SHGC-22	0.350	ne	0.00	0.00	0	0	0	0	0	0	0	0
	W	14E-0	0.388	se	27.16	4.04	115	100	2718	404	0	0	0	0
	└G	U-35 SHGC-27	0.350	se	24.50	26.77	15	0	359	393	0	0	0	0
	└D	11D0	0.390	se	0.00	0.00	0	0	0	0	0	0	0	0
	W	15B-0c-8	0.488	se	0.00	0.00	0	0	0	0	0	0	0	0
	└G	U-35 SHGC-27	0.350	se	0.00	0.00	0	0	0	0	0	0	0	0
	W	15B13-0wc-8	0.093	se	0.00	0.00	0	0	0	0	0	0	0	0
	W	STD - Frame - R-19 -	0.064	se	4.48	1.19	0	0	0	0	0	0	0	0
	└G	U-35 SHGC-22	0.350	se	24.50	22.84	0	0	0	0	0	0	0	0
	W	14E-0	0.388	s	0.00	0.00	0	0	0	0	0	0	0	0
	└G	U-35 SHGC-27	0.350	s	0.00	0.00	0	0	0	0	0	0	0	0
	W	14E-0	0.388	sw	27.16	4.04	0	0	0	0	0	0	0	0
	└G	U-35 SHGC-22	0.350	sw	0.00	0.00	0	0	0	0	0	0	0	0
	└G	U-35 SHGC-27	0.350	sw	24.50	26.77	0	0	0	0	0	0	0	0
	└G	U-35 SHGC-27 GD	0.350	sw	0.00	0.00	0	0	0	0	0	0	0	0
	W	15B-0c-8	0.488	sw	0.00	0.00	0	0	0	0	0	0	0	0
	W	15B13-0wc-8	0.093	sw	0.00	0.00	0	0	0	0	0	0	0	0
	W	STD - Frame - R-19 -	0.064	sw	4.48	1.19	0	0	0	0	0	0	0	0
	└G	U-35 SHGC-22	0.350	sw	24.50	22.84	0	0	0	0	0	0	0	0
	└G	U-35 SHGC-22 GD	0.350	sw	0.00	0.00	0	0	0	0	0	0	0	0
	W	14E-0	0.388	w	0.00	0.00	0	0	0	0	0	0	0	0
	└G	U-35 SHGC-22	0.350	w	0.00	0.00	0	0	0	0	0	0	0	0
	W	15B-0c-8	0.488	w	0.00	0.00	0	0	0	0	0	0	0	0
	W	14E-0	0.388	nw	27.16	4.04	0	0	0	0	0	0	0	0
	└G	U-35 SHGC-22	0.350	nw	0.00	0.00	0	0	0	0	0	0	0	0
	└G	U-35 SHGC-27	0.350	nw	24.50	22.31	0	0	0	0	0	0	0	0
	└G	U-35 SHGC-27 GD	0.350	nw	24.50	22.31	0	0	0	0	0	0	0	0
	W	15B-0c-8	0.488	nw	0.00	0.00	0	0	0	0	0	0	0	0
	W	15B13-0wc-8	0.093	nw	0.00	0.00	0	0	0	0	0	0	0	0
	W	STD - Frame - R-19 -	0.064	nw	4.48	1.19	0	0	0	0	0	0	0	0
	└G	U-35 SHGC-22	0.350	nw	24.50	19.20	0	0	0	0	0	0	0	0
	C	STD - Attic CLG - R-	0.034	-	0.00	0.00	0	0	0	0	0	0	0	0
	└C	STD - Attic CLG - R-	0.027	-	1.87	1.26	196	180	337	227	42	42	79	53
	└G	Skylight - U-35 SHGC	0.350	-	24.50	78.50	16	0	392	1256	0	0	0	0
	└G	Skylight - U-29 SHGC	0.290	ne	0.00	0.00	0	0	0	0	0	0	0	0
6	c) AED excursion									-92				-5
	Envelope loss/gain							4662	2314			376	127	
12	a) Infiltration							169	20			54	7	
	b) Room ventilation							0	0			0	0	
13	Internal gains:	Occupants @	230				0			0	0			0
		Appliances/other								0				0
	Subtotal (lines 6 to 13)							4831	2335			430	134	
	Less external load							0	0			0	0	
	Less transfer							0	0			0	0	
	Redistribution							0	0			0	0	
	Subtotal							4831	2335			430	134	
14	Duct loads						17%	37%	817	872	17%	37%	73	50
	Total room load							5647	3207			503	183	
	Air required (cfm)							129	182			11	10	

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.





# Right-J® Worksheet

## Upper Zone

Authority Air Designs, LLC.

**Job:** Sample Address  
**Date:** Oct 12, 2012  
**By:** Joe Colburn  
**Plan:** Sample Design

6608 W. 95th Place, Westminster, CO 80021-6422 Phone: (720) 354-8105 Fax: (720) 254-8105 Email: Joe@AuthorityAir.com Web: www.AuthorityAir.com

1		Room name		Bedroom 2				Bath 1						
2		Exposed wall		42.0 ft				7.2 ft						
3		Room height		9.0 ft				9.0 ft						
4		Room dimensions		1.0 x 254.9 ft				7.7 x 9.8 ft						
5		Room area		254.9 ft²				75.4 ft²						
	Ty	Construction number	U-value (Btuh/ft²·°F)	Or	HTM (Btuh/ft²)		Area (ft²) or perimeter (ft)		Load (Btuh)		Area (ft²) or perimeter (ft)		Load (Btuh)	
					Heat	Cool	Gross	N/P/S	Heat	Cool	Gross	N/P/S	Heat	Cool
6	W	14E-0	0.388	n	0.00	0.00	0	0	0	0	0	0	0	0
	G	U-35 SHGC-22	0.350	n	0.00	0.00	0	0	0	0	0	0	0	0
	W	15B-0c-8	0.488	n	0.00	0.00	0	0	0	0	0	0	0	0
	W	12C-0bw	0.091	ne	0.00	0.00	0	0	0	0	0	0	0	0
11	G	U-35 SHGC-27	0.350	ne	0.00	0.00	0	0	0	0	0	0	0	0
	G	U-35 SHGC-27 GD	0.350	ne	0.00	0.00	0	0	0	0	0	0	0	0
	W	14E-0	0.388	ne	27.16	4.04	179	155	4217	626	0	0	0	0
	G	U-35 SHGC-22	0.350	ne	0.00	0.00	0	0	0	0	0	0	0	0
	G	U-35 SHGC-27	0.350	ne	24.50	22.31	24	0	588	535	0	0	0	0
	D	11D0	0.390	ne	0.00	0.00	0	0	0	0	0	0	0	0
	W	15B-0c-8	0.488	ne	0.00	0.00	0	0	0	0	0	0	0	0
	D	11D0	0.390	ne	0.00	0.00	0	0	0	0	0	0	0	0
	W	15B13-0wc-8	0.093	ne	0.00	0.00	0	0	0	0	0	0	0	0
	W	STD - Frame - R-13 -	0.090	ne	6.28	1.67	0	0	0	0	0	0	0	0
	W	STD - Frame - R-19 -	0.064	ne	4.48	1.19	0	0	0	0	0	0	0	0
	G	U-35 SHGC-22	0.350	ne	0.00	0.00	0	0	0	0	0	0	0	0
	W	14E-0	0.388	se	27.16	4.04	77	77	2078	309	0	0	0	0
	G	U-35 SHGC-27	0.350	se	24.50	26.77	0	0	0	0	0	0	0	0
	D	11D0	0.390	se	0.00	0.00	0	0	0	0	0	0	0	0
	W	15B-0c-8	0.488	se	0.00	0.00	0	0	0	0	0	0	0	0
	G	U-35 SHGC-27	0.350	se	0.00	0.00	0	0	0	0	0	0	0	0
	W	15B13-0wc-8	0.093	se	0.00	0.00	0	0	0	0	0	0	0	0
	W	STD - Frame - R-19 -	0.064	se	4.48	1.19	0	0	0	0	0	0	0	0
	G	U-35 SHGC-22	0.350	se	24.50	22.84	0	0	0	0	0	0	0	0
	W	14E-0	0.388	s	0.00	0.00	0	0	0	0	0	0	0	0
	G	U-35 SHGC-27	0.350	s	0.00	0.00	0	0	0	0	0	0	0	0
	W	14E-0	0.388	sw	27.16	4.04	0	0	0	0	0	0	0	0
	G	U-35 SHGC-22	0.350	sw	0.00	0.00	0	0	0	0	0	0	0	0
	G	U-35 SHGC-27	0.350	sw	24.50	26.77	0	0	0	0	0	0	0	0
	G	U-35 SHGC-27 GD	0.350	sw	0.00	0.00	0	0	0	0	0	0	0	0
	W	15B-0c-8	0.488	sw	0.00	0.00	0	0	0	0	0	0	0	0
	W	15B13-0wc-8	0.093	sw	0.00	0.00	0	0	0	0	0	0	0	0
	W	STD - Frame - R-19 -	0.064	sw	4.48	1.19	0	0	0	0	0	0	0	0
	G	U-35 SHGC-22	0.350	sw	24.50	22.84	0	0	0	0	0	0	0	0
	G	U-35 SHGC-22 GD	0.350	sw	0.00	0.00	0	0	0	0	0	0	0	0
	W	14E-0	0.388	w	0.00	0.00	0	0	0	0	0	0	0	0
	G	U-35 SHGC-22	0.350	w	0.00	0.00	0	0	0	0	0	0	0	0
	W	15B-0c-8	0.488	w	0.00	0.00	0	0	0	0	0	0	0	0
	W	14E-0	0.388	nw	27.16	4.04	122	110	2994	445	65	53	1426	212
	G	U-35 SHGC-22	0.350	nw	0.00	0.00	0	0	0	0	0	0	0	0
	G	U-35 SHGC-27	0.350	nw	24.50	22.31	12	0	294	268	12	0	294	268
	G	U-35 SHGC-27 GD	0.350	nw	24.50	22.31	0	0	0	0	0	0	0	0
	W	15B-0c-8	0.488	nw	0.00	0.00	0	0	0	0	0	0	0	0
	W	15B13-0wc-8	0.093	nw	0.00	0.00	0	0	0	0	0	0	0	0
	W	STD - Frame - R-19 -	0.064	nw	4.48	1.19	0	0	0	0	0	0	0	0
	G	U-35 SHGC-22	0.350	nw	24.50	19.20	0	0	0	0	0	0	0	0
	C	STD - Attic CLG - R-	0.034	-	0.00	0.00	0	0	0	0	0	0	0	0
	C	STD - Attic CLG - R-	0.027	-	1.87	1.26	255	255	478	321	75	75	141	95
	G	Skylight - U-35 SHGC	0.350	-	24.50	78.50	0	0	0	0	0	0	0	0
	G	Skylight - U-29 SHGC	0.290	ne	0.00	0.00	0	0	0	0	0	0	0	0
6	c) AED excursion									-97				81
	Envelope loss/gain								10648	2408			1861	656
12	a) Infiltration								436	53			74	9
	b) Room ventilation								0	0			0	0
13	Internal gains:			Occupants @	230		0			0	0			0
				Appliances/other						0				0
	Subtotal (lines 6 to 13)								11084	2461			1936	665
	Less external load								0	0			0	0
	Less transfer								0	0			0	0
	Redistribution								0	0			0	0
14	Subtotal								11084	2461			1936	665
15	Duct loads						17%	37%	1874	919	17%	37%	327	248
	Total room load								12959	3380			2263	914
	Air required (cfm)								295	192			52	52

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.











# Load Short Form

## Entire House

Authority Air Designs, LLC.

Job: Sample Address  
 Date: Oct 12, 2012  
 By: Joe Colburn  
 Plan: Sample Design

6608 W. 95th Place, Westminster, CO 80021-6422 Phone: (720) 354-8105 Fax: (720) 254-8105 Email: Joe@AuthorityAir.com Web: www.AuthorityAir.com

### Project Information

For: Sample Two  
 Sample Address, Denver, CO 80000  
 Phone: (720) 354-8105 Fax: (720) 354-8105  
 Web: www.SampleWebsite.com Email: Sample@Email.com

### Design Information

	Htg	Clg	Method	Infiltration
Outside db (°F)	0	91	Method	Simplified
Inside db (°F)	70	75	Construction quality	Tight
Design TD (°F)	70	16	Fireplaces	1 (Tight)
Daily range	-	H		
Inside humidity (%)	50	50		
Moisture difference (gr/lb)	61	-34		

#### HEATING EQUIPMENT

Make n/a  
 Trade n/a  
 Model n/a  
 AHRI ref n/a

Efficiency n/a  
 Heating input  
 Heating output 0 Btuh  
 Temperature rise 0 °F  
 Actual air flow 0 cfm  
 Air flow factor 0 cfm/Btuh  
 Static pressure 0 in H2O  
 Space thermostat n/a

#### COOLING EQUIPMENT

Make n/a  
 Trade n/a  
 Cond n/a  
 Coil n/a  
 AHRI ref n/a

Efficiency n/a  
 Sensible cooling 0 Btuh  
 Latent cooling 0 Btuh  
 Total cooling 0 Btuh  
 Actual air flow 0 cfm  
 Air flow factor 0 cfm/Btuh  
 Static pressure 0 in H2O  
 Load sensible heat ratio 0

ROOM NAME	Area (ft²)	Htg load (Btuh)	Clg load (Btuh)	Htg AVF (cfm)	Clg AVF (cfm)
Basement Zone d	536	3676	0	43	0
Main Zone d	3846	62844	18004	1400	1400
Conservatory Zone d	580	22944	17325	1000	1000
Upper Zone d	1967	61431	24644	1400	1400
Entire House d	6930	150895	59365	3843	3800
Other equip loads		18423	3293		
Equip. @ 0.96 RSM			60026		
Latent cooling			0		
<b>TOTALS</b>	<b>6930</b>	<b>169318</b>	<b>60026</b>	<b>3843</b>	<b>3800</b>

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



**Load Short Form**  
**Basement Zone**  
 Authority Air Designs, LLC.

Job: Sample Address  
 Date: Oct 12, 2012  
 By: Joe Colburn  
 Plan: Sample Design

6608 W. 95th Place, Westminster, CO 80021-6422 Phone: (720) 354-8105 Fax: (720) 254-8105 Email: Joe@AuthorityAir.com Web: www.AuthorityAir.com

**Project Information**

For: Sample Two  
 Sample Address, Denver, CO 80000  
 Phone: (720) 354-8105 Fax: (720) 354-8105  
 Web: www.SampleWebsite.com Email: Sample@Email.com

**Design Information**

	Htg	Clg	Method	Infiltration
Outside db (°F)	0	91	Method	Simplified
Inside db (°F)	70	75	Construction quality	Tight
Design TD (°F)	70	16	Fireplaces	1 (Tight)
Daily range	-	H		
Inside humidity (%)	50	50		
Moisture difference (gr/lb)	61	-34		

**HEATING EQUIPMENT**

Make  
 Trade  
 Model  
 AHRI ref  
 Efficiency 80 AFUE  
 Heating input 0 MBtuh  
 Heating output 0 Btuh  
 Temperature rise 0 °F  
 Actual air flow 0 cfm  
 Air flow factor 0 cfm/Btuh  
 Static pressure 0 in H2O  
 Space thermostat

**COOLING EQUIPMENT**

Make  
 Trade  
 Cond  
 Coil  
 AHRI ref  
 Efficiency 0 SEER  
 Sensible cooling 0 Btuh  
 Latent cooling 0 Btuh  
 Total cooling 0 Btuh  
 Actual air flow 0 cfm  
 Air flow factor 0 cfm/Btuh  
 Static pressure 0 in H2O  
 Load sensible heat ratio 0

ROOM NAME	Area (ft²)	Htg load (Btuh)	Clg load (Btuh)	Htg AVF (cfm)	Clg AVF (cfm)
Dn Library	385	2233	0	26	0
Dn Mech 1	95	856	0	10	0
Dn Storage	56	587	0	7	0
Basement Zone	d 536	3676	0	43	0
Other equip loads		334	0		
Equip. @ 0.96 RSM			0		
Latent cooling			0		
<b>TOTALS</b>	<b>536</b>	<b>4010</b>	<b>0</b>	<b>43</b>	<b>0</b>

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



# Load Short Form Conservatory Zone

Authority Air Designs, LLC.

Job: Sample Address  
Date: Oct 12, 2012  
By: Joe Colburn  
Plan: Sample Design

6608 W. 95th Place, Westminster, CO 80021-6422 Phone: (720) 354-8105 Fax: (720) 254-8105 Email: Joe@AuthorityAir.com Web: www.AuthorityAir.com

## Project Information

For: Sample Two  
Sample Address, Denver, CO 80000  
Phone: (720) 354-8105 Fax: (720) 354-8105  
Web: www.SampleWebsite.com Email: Sample@Email.com

## Design Information

	Htg	Clg		Infiltration
Outside db (°F)	0	91	Method	Simplified
Inside db (°F)	70	75	Construction quality	Tight
Design TD (°F)	70	16	Fireplaces	1 (Tight)
Daily range	-	H		
Inside humidity (%)	50	50		
Moisture difference (gr/lb)	61	-34		

### HEATING EQUIPMENT

Make Carrier  
Trade Carrier  
Model 59SP5A060E17-14  
AHRI ref 4702805

Efficiency 96.5 AFUE  
Heating input 47520 MBtuh  
Heating output 45936 Btuh  
Temperature rise 51 °F  
Actual air flow 1000 cfm  
Air flow factor 0.044 cfm/Btuh  
Static pressure 1.00 in H2O  
Space thermostat

### COOLING EQUIPMENT

Make Carrier  
Trade Comfort 13  
Cond 24ABB324A31  
Coil CNPVP3617A  
AHRI ref 3250468

Efficiency 12.2 EER, 14.5 SEER  
Sensible cooling 19890 Btuh  
Latent cooling 3510 Btuh  
Total cooling 23400 Btuh  
Actual air flow 1000 cfm  
Air flow factor 0.058 cfm/Btuh  
Static pressure 1.00 in H2O  
Load sensible heat ratio 1.00

ROOM NAME	Area (ft²)	Htg load (Btuh)	Clg load (Btuh)	Htg AVF (cfm)	Clg AVF (cfm)
Conservatory	580	22944	17325	1000	1000
Conservatory Zone	580	22944	17325	1000	1000
Other equip loads		5742	593		
Equip. @ 0.96 RSM			17165		
Latent cooling			0		
<b>TOTALS</b>	<b>580</b>	<b>28686</b>	<b>17165</b>	<b>1000</b>	<b>1000</b>

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



**Load Short Form**  
**Main Zone**  
 Authority Air Designs, LLC.

Job: Sample Address  
 Date: Oct 12, 2012  
 By: Joe Colburn  
 Plan: Sample Design

6608 W. 95th Place, Westminster, CO 80021-6422 Phone: (720) 354-8105 Fax: (720) 254-8105 Email: Joe@AuthorityAir.com Web: www.AuthorityAir.com

**Project Information**

For: Sample Two  
 Sample Address, Denver, CO 80000  
 Phone: (720) 354-8105 Fax: (720) 354-8105  
 Web: www.SampleWebsite.com Email: Sample@Email.com

**Design Information**

	Htg	Clg	Method	Infiltration
Outside db (°F)	0	91	Method	Simplified
Inside db (°F)	70	75	Construction quality	Tight
Design TD (°F)	70	16	Fireplaces	1 (Tight)
Daily range	-	H		
Inside humidity (%)	50	50		
Moisture difference (gr/lb)	61	-34		

**HEATING EQUIPMENT**

Make Carrier  
 Trade Carrier  
 Model 59SP5A100E21-20  
 AHRI ref 4702807

Efficiency 96.5 AFUE  
 Heating input 79200 MBtuh  
 Heating output 77616 Btuh  
 Temperature rise 61 °F  
 Actual air flow 1400 cfm  
 Air flow factor 0.022 cfm/Btuh  
 Static pressure 1.00 in H2O  
 Space thermostat

**COOLING EQUIPMENT**

Make Carrier  
 Trade Comfort 13  
 Cond 24ABB330A31  
 Coil CNPVP3621A  
 AHRI ref 3250525

Efficiency 10.8 EER, 13 SEER  
 Sensible cooling 23290 Btuh  
 Latent cooling 4110 Btuh  
 Total cooling 27400 Btuh  
 Actual air flow 1400 cfm  
 Air flow factor 0.078 cfm/Btuh  
 Static pressure 1.00 in H2O  
 Load sensible heat ratio 1.00

ROOM NAME	Area (ft²)	Htg load (Btuh)	Clg load (Btuh)	Htg AVF (cfm)	Clg AVF (cfm)
Library	536	8492	5837	189	454
Living	628	13954	3491	311	272
Entry	175	3231	591	72	46
Powder	50	2359	336	53	26
K Entry	76	4296	892	96	69
Dining	302	9139	3934	204	306
Kitchen	370	4341	2092	97	163
Pantry	34	748	229	17	18
Nook	93	2080	601	46	47
Dn Mech 2	301	3159	0	70	0
Dn Bath	123	1646	0	37	0
Dn Bedroom	392	4334	0	97	0
Dn Game	765	5065	0	113	0

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.

Main Zone	d	3846	62844	18004	1400	1400
Other equip loads			14163	1529		
Equip. @ 0.96 RSM				18712		
Latent cooling				0		
TOTALS		3846	77007	18712	1400	1400

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



# Load Short Form

## Upper Zone

Authority Air Designs, LLC.

Job: Sample Address  
 Date: Oct 12, 2012  
 By: Joe Colburn  
 Plan: Sample Design

6608 W. 95th Place, Westminster, CO 80021-6422 Phone: (720) 354-8105 Fax: (720) 254-8105 Email: Joe@AuthorityAir.com Web: www.AuthorityAir.com

### Project Information

For: Sample Two  
 Sample Address, Denver, CO 80000  
 Phone: (720) 354-8105 Fax: (720) 354-8105  
 Web: www.SampleWebsite.com Email: Sample@Email.com

### Design Information

	Htg	Clg	Method	Infiltration
Outside db (°F)	0	91	Method	Simplified
Inside db (°F)	70	75	Construction quality	Tight
Design TD (°F)	70	16	Fireplaces	1 (Tight)
Daily range	-	H		
Inside humidity (%)	50	50		
Moisture difference (gr/lb)	61	-34		

#### HEATING EQUIPMENT

Make Carrier  
 Trade Carrier  
 Model 59SP5A100E21-20  
 AHRI ref 5285422

Efficiency 96.3 AFUE  
 Heating input 79200 MBtuh  
 Heating output 76824 Btuh  
 Temperature rise 61 °F  
 Actual air flow 1400 cfm  
 Air flow factor 0.023 cfm/Btuh  
 Static pressure 1.00 in H2O  
 Space thermostat

#### COOLING EQUIPMENT

Make Carrier  
 Trade Base 13  
 Cond 24ABB336A31  
 Coil CNPHP4821A  
 AHRI ref 4741459

Efficiency 11.7 EER, 14 SEER  
 Sensible cooling 28900 Btuh  
 Latent cooling 5100 Btuh  
 Total cooling 34000 Btuh  
 Actual air flow 1400 cfm  
 Air flow factor 0.057 cfm/Btuh  
 Static pressure 1.00 in H2O  
 Load sensible heat ratio 1.00

ROOM NAME	Area (ft²)	Htg load (Btuh)	Clg load (Btuh)	Htg AVF (cfm)	Clg AVF (cfm)
Dressing	441	8631	6125	197	348
Hall	196	5647	3207	129	182
Bath 2	42	503	183	11	10
Bedroom 2	255	12959	3380	295	192
Bath 1	75	2263	914	52	52
M Bath	187	5053	1919	115	109
Bedroom 1	318	12191	3713	278	211
M Bedroom	452	14183	5203	323	296

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.

Upper Zone	d	1967	61431	24644	1400	1400
Other equip loads			11109	1172		
Equip. @ 0.96 RSM				24732		
Latent cooling				0		
TOTALS		1967	72540	24732	1400	1400

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.





# Load Multizone Summary Report

Authority Air Designs, LLC.

Job: Sample Address  
 Date: Oct 12, 2012  
 By: Joe Colburn  
 Plan: Sample Design

6608 W. 95th Place, Westminster, CO 80021-6422 Phone: (720) 354-8105 Fax: (720) 254-8105 Email: Joe@AuthorityAir.com Web: www.AuthorityAir.com

## Infiltration Summary

ZONE NAME	Heating				Cooling			
	Volume ft³	ACH	AVF cfm	HTM Btuh/ft²	Volume ft³	ACH	AVF cfm	HTM Btuh/ft²
Basement Zone	536	0.17	2	1.2	0	0	0	0
Main Zone	21941	0.12	42	1.2	20384	0.06	21	0.1
Conservatory Zone	9286	0.15	24	1.2	9286	0.08	13	0.1
Upper Zone	17707	0.13	40	1.2	17707	0.07	21	0.1
Entire House	49471	0.13	107	1.2	47377	0.07	55	0.1

## Load and AVF Summary

ROOM NAME	Area ft²	Htg load Btuh	Clg load Btuh	Htg AVF cfm	Clg AVF cfm
Dn Library	385	2233	0	26	0
Dn Mech 1	95	856	0	10	0
Dn Storage	56	587	0	7	0
Basement Zone	536	3676	0	43	0
Library	536	8492	5837	189	454
Living	628	13954	3491	311	272
Entry	175	3231	591	72	46
Powder	50	2359	336	53	26
K Entry	76	4296	892	96	69
Dining	302	9139	3934	204	306
Kitchen	370	4341	2092	97	163
Pantry	34	748	229	17	18
Nook	93	2080	601	46	47
Dn Mech 2	301	3159	0	70	0
Dn Bath	123	1646	0	37	0
Dn Bedroom	392	4334	0	97	0
Dn Game	765	5065	0	113	0
Main Zone	3846	62844	18004	1400	1400
Conservatory	580	22944	17325	1000	1000
Conservatory Zone	580	22944	17325	1000	1000
Dressing	441	8631	6125	197	348
Hall	196	5647	3207	129	182
Bath 2	42	503	183	11	10
Bedroom 2	255	12959	3380	295	192
Bath 1	75	2263	914	52	52
M Bath	187	5053	1919	115	109
Bedroom 1	318	12191	3713	278	211
M Bedroom	452	14183	5203	323	296
Upper Zone	1967	61431	24644	1400	1400
Entire House	6930	150895	59365	3843	3800



# Duct System Summary

## Basement Zone

Authority Air Designs, LLC.

Job: Sample Address  
Date: Oct 12, 2012  
By: Joe Colburn  
Plan: Sample Design

6608 W. 95th Place, Westminster, CO 80021-6422 Phone: (720) 354-8105 Fax: (720) 254-8105 Email: Joe@AuthorityAir.com Web: www.AuthorityAir.com

### Project Information

For: Sample Two  
Sample Address, Denver, CO 80000  
Phone: (720) 354-8105 Fax: (720) 354-8105  
Web: www.SampleWebsite.com Email: Sample@Email.com

	Heating	Cooling
External static pressure	0 in H2O	0 in H2O
Pressure losses	0 in H2O	0 in H2O
Available static pressure	0 in H2O	0 in H2O
Supply / return available pressure	0.00 / 0.00 in H2O	0.00 / 0.00 in H2O
Lowest friction rate	0 in/100ft	0 in/100ft
Actual air flow	0 cfm	0 cfm
Total effective length (TEL)		0 ft



# Duct System Summary

## Conservatory Zone

Authority Air Designs, LLC.

Job: Sample Address  
 Date: Oct 12, 2012  
 By: Joe Colburn  
 Plan: Sample Design

6608 W. 95th Place, Westminster, CO 80021-6422 Phone: (720) 354-8105 Fax: (720) 254-8105 Email: Joe@AuthorityAir.com Web: www.AuthorityAir.com

### Project Information

For: Sample Two  
 Sample Address, Denver, CO 80000  
 Phone: (720) 354-8105 Fax: (720) 354-8105  
 Web: www.SampleWebsite.com Email: Sample@Email.com

	Heating	Cooling
External static pressure	1.00 in H2O	1.00 in H2O
Pressure losses	0.40 in H2O	0.40 in H2O
Available static pressure	0.60 in H2O	0.60 in H2O
Supply / return available pressure	0.39 / 0.21 in H2O	0.39 / 0.21 in H2O
Lowest friction rate	0.153 in/100ft	0.153 in/100ft
Actual air flow	1000 cfm	1000 cfm
Total effective length (TEL)		392 ft

### Supply Branch Detail Table

Name	Design (Btuh)	Htg (cfm)	Clg (cfm)	Design FR	Diam (in)	H x W (in)	Duct Matl	Actual Ln (ft)	Ftg.Eqv Ln (ft)	Trunk
Conservatory-E	c 3278	143	143	0.184	6.0	0x0	ShMt	12.0	200.0	st2
Conservatory-F	c 3278	143	143	0.168	6.0	0x0	ShMt	32.2	200.0	st2
Conservatory-G	c 3278	143	143	0.186	6.0	0x0	ShMt	24.7	185.0	st2
Conservatory-I	c 3278	143	143	0.153	7.0	0x0	ShMt	29.6	225.0	st2
Conservatory-J	c 3278	143	143	0.154	7.0	0x0	ShMt	43.2	210.0	st2
Conservatory-K	c 3278	143	143	0.190	6.0	0x0	ShMt	20.5	185.0	st2
Conservatory-L	c 3278	143	143	0.173	6.0	0x0	ShMt	35.2	190.0	st2

### Supply Trunk Detail Table

Name	Trunk Type	Htg (cfm)	Clg (cfm)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Duct Material	Trunk
st2	Peak AVF	1000	1000	0.153	842	14.3	10 x 20	DctLinr	

### Return Branch Detail Table

Name	Grill Size (in)	Htg (cfm)	Clg (cfm)	TEL (ft)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Stud/Joist Opening (in)	Duct Matl	Trunk
rb4	10x21	571	571	137.2	0.153	610	11.9	10x 16		DcLn	rt2
rb13	6x33	429	429	120.2	0.175	643	9.0	8x 12		ShMt	rt2

## Return Trunk Detail Table

Name	Trunk Type	Htg (cfm)	Clg (cfm)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Duct Material	Trunk
rt2	Peak AVF	1000	1000	0.153	696	14.3	10 x 24	DctLinr	



# Duct System Summary

## Main Zone

Authority Air Designs, LLC.

Job: Sample Address  
 Date: Oct 12, 2012  
 By: Joe Colburn  
 Plan: Sample Design

6608 W. 95th Place, Westminster, CO 80021-6422 Phone: (720) 354-8105 Fax: (720) 254-8105 Email: Joe@AuthorityAir.com Web: www.AuthorityAir.com

### Project Information

For: Sample Two  
 Sample Address, Denver, CO 80000  
 Phone: (720) 354-8105 Fax: (720) 354-8105  
 Web: www.SampleWebsite.com Email: Sample@Email.com

	Heating	Cooling
External static pressure	1.00 in H2O	1.00 in H2O
Pressure losses	0.44 in H2O	0.44 in H2O
Available static pressure	0.56 in H2O	0.56 in H2O
Supply / return available pressure	0.28 / 0.28 in H2O	0.28 / 0.28 in H2O
Lowest friction rate	0.086 in/100ft	0.086 in/100ft
Actual air flow	1400 cfm	1400 cfm
Total effective length (TEL)	649 ft	

### Supply Branch Detail Table

Name	Design (Btuh)	Htg (cfm)	Clg (cfm)	Design FR	Diam (in)	H x W (in)	Duct Matl	Actual Ln (ft)	Ftg.Eqv Ln (ft)	Trunk
Dining	c 1311	68	102	0.100	6.0	0x0	ShMt	19.2	260.0	st3
Dining-A	c 1311	68	102	0.089	6.0	0x0	ShMt	23.8	290.0	st3
Dining-B	c 1311	68	102	0.100	6.0	0x0	ShMt	11.7	265.0	st3
Dn Bath	h 1646	37	0	0.091	5.0	0x0	ShMt	49.3	255.0	st3
Dn Bedroom	h 4334	97	0	0.108	6.0	0x0	ShMt	33.4	225.0	st3
Dn Game	h 2532	56	0	0.098	5.0	0x0	ShMt	38.3	245.0	st4
Dn Game-A	h 2532	56	0	0.101	5.0	0x0	ShMt	26.6	250.0	st4
Dn Mech 2	h 3159	70	0	0.102	6.0	0x0	ShMt	18.7	255.0	st3
Entry	h 3231	72	46	0.088	6.0	0x0	ShMt	27.5	290.0	st4
K Entry	h 4296	96	69	0.094	6.0	0x0	ShMt	45.3	250.0	st3
Kitchen	c 1046	48	81	0.089	6.0	0x0	ShMt	43.4	270.0	st3
Kitchen-A	c 1046	48	81	0.102	6.0	0x0	ShMt	33.1	240.0	st3
Library-A	c 1459	47	113	0.086	7.0	0x0	ShMt	62.1	260.0	st4
Library-B	c 1459	47	113	0.092	7.0	0x0	ShMt	42.3	260.0	st4A
Library-C	c 1459	47	113	0.089	7.0	0x0	ShMt	56.3	255.0	st4A
Library-D	c 1459	47	113	0.094	7.0	0x0	ShMt	50.4	245.0	st4A
Living	h 4651	104	91	0.100	6.0	0x0	ShMt	22.8	255.0	st4
Living-A	h 4651	104	91	0.099	6.0	0x0	ShMt	41.6	240.0	st4
Living-B	h 4651	104	91	0.105	6.0	0x0	ShMt	30.4	235.0	st4
Nook	c 601	46	47	0.098	5.0	0x0	ShMt	38.9	245.0	st3
Pantry	c 229	17	18	0.100	4.0	0x0	ShMt	22.9	255.0	st3
Powder	h 2359	53	26	0.092	5.0	0x0	ShMt	46.9	255.0	st3

## Supply Trunk Detail Table

Name	Trunk Type	Htg (cfm)	Clg (cfm)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Duct Material	Trunk
st4A	Peak AVF	142	340	0.089	438	9.4	8 x 14	ShtMetl	st4
st4	Peak AVF	685	771	0.086	771	12.9	8 x 18	ShtMetl	
st3	Peak AVF	715	629	0.089	715	12.5	8 x 18	ShtMetl	

## Return Branch Detail Table

Name	Grill Size (in)	Htg (cfm)	Clg (cfm)	TEL (ft)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Stud/Joist Opening (in)	Duct Matl	Trunk
rb1	0x0	171	149	326.8	0.086	489	8.0	0x 0		ShMt	rt4
rb2	20x 17	704	725	290.3	0.097	594	12.2	8x 22		ShMt	rt4
rb6	0x0	216	197	216.4	0.130	619	8.0	0x 0		ShMt	rt5
rb10	6x 15	193	145	189.8	0.149	554	8.0	0x 0		ShMt	rt5
rb9	6x 14	116	183	321.0	0.088	525	8.0	0x 0		ShMt	rt5

## Return Trunk Detail Table

Name	Trunk Type	Htg (cfm)	Clg (cfm)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Duct Material	Trunk
rt4	Peak AVF	874	874	0.086	715	13.5	8 x 22	ShtMetl	rt3
rt5	Peak AVF	526	526	0.088	430	11.5	8 x 22	ShtMetl	
rt3	Peak AVF	1400	1400	0.086	600	16.1	14 x 24	ShtMetl	



# Duct System Summary

## Upper Zone

Authority Air Designs, LLC.

Job: Sample Address  
 Date: Oct 12, 2012  
 By: Joe Colburn  
 Plan: Sample Design

6608 W. 95th Place, Westminster, CO 80021-6422 Phone: (720) 354-8105 Fax: (720) 254-8105 Email: Joe@AuthorityAir.com Web: www.AuthorityAir.com

### Project Information

For: Sample Two  
 Sample Address, Denver, CO 80000  
 Phone: (720) 354-8105 Fax: (720) 354-8105  
 Web: www.SampleWebsite.com Email: Sample@Email.com

	Heating	Cooling
External static pressure	1.00 in H2O	1.00 in H2O
Pressure losses	0.33 in H2O	0.33 in H2O
Available static pressure	0.67 in H2O	0.67 in H2O
Supply / return available pressure	0.48 / 0.19 in H2O	0.48 / 0.19 in H2O
Lowest friction rate	0.072 in/100ft	0.072 in/100ft
Actual air flow	1400 cfm	1400 cfm
Total effective length (TEL)	931 ft	

### Supply Branch Detail Table

Name	Design (Btuh)	Htg (cfm)	Clg (cfm)	Design FR	Diam (in)	H x W (in)	Duct Matl	Actual Ln (ft)	Ftg.Eqv Ln (ft)	Trunk
Bath 1	c 914	52	52	0.076	6.0	0x0	VIFx	28.5	600.0	st1
Bath 2	h 503	11	10	0.101	4.0	0x0	VIFx	37.6	435.0	st1
Bedroom 1	h 6096	139	105	0.077	8.0	0x0	VIFx	21.8	600.0	st1
Bedroom 1-A	h 6096	139	105	0.072	8.0	0x0	VIFx	28.8	635.0	st1
Bedroom 2	h 6479	148	96	0.083	8.0	0x0	VIFx	37.3	535.0	st1
Bedroom 2-A	h 6479	148	96	0.076	8.0	0x0	VIFx	38.3	590.0	st1
Dressing	c 2042	66	116	0.099	8.0	0x0	VIFx	47.9	435.0	st1
Dressing-A	c 2042	66	116	0.077	8.0	0x0	VIFx	47.5	570.0	st1
Dressing-B	c 2042	66	116	0.091	8.0	0x0	VIFx	53.8	470.0	st1
Hall	c 1603	64	91	0.124	7.0	0x0	VIFx	29.1	355.0	st1
Hall-A	c 1603	64	91	0.102	7.0	0x0	VIFx	35.5	435.0	st1
M Bath	h 5053	115	109	0.215	6.0	0x0	VIFx	16.7	205.0	st1
M Bedroom	h 4728	108	99	0.078	8.0	0x0	VIFx	24.5	590.0	st1
M Bedroom-A	h 4728	108	99	0.182	7.0	0x0	VIFx	23.0	240.0	st1
M Bedroom-B	h 4728	108	99	0.137	7.0	0x0	VIFx	29.8	320.0	st1

### Supply Trunk Detail Table

Name	Trunk Type	Htg (cfm)	Clg (cfm)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Duct Material	Trunk
st1	Peak AVF	1400	1400	0.072	698	18.6	18 x 18	DctLinr	


## Return Branch Detail Table

Name	Grill Size (in)	Htg (cfm)	Clg (cfm)	TEL (ft)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Stud/Joist Opening (in)	Duct Matl	Trunk
rb5	0x0	197	348	161.9	0.119	443	12.0	0x 0		VIFx	rt1
rb3	16x 13	438	405	75.8	0.254	558	12.0	0x 0		VIFx	rt1
rb7	14x 10	307	202	267.3	0.072	391	12.0	0x 0		VIFx	rt1
rb11	12x 7	129	182	120.3	0.160	522	8.0	0x 0		VIFx	rt1
rb8	14x 11	329	263	85.0	0.226	604	10.0	0x 0		VIFx	rt1


## Return Trunk Detail Table

Name	Trunk Type	Htg (cfm)	Clg (cfm)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Duct Material	Trunk
rt1	Peak AVF	1400	1400	0.072	698	18.6	18 x 18	DctLinr	






### Basement





**Job #: Sample Address**  
**Performed by Joe Colburn for:**  
Sample Two  
Sample Address  
Denver, CO 80000  
Phone: (720) 354-8105 Fax: (720) 354-8105  
www.SampleWebsite.com Sample@Email.com

**Authority Air Designs, LLC.**  
6608 W. 95th Place  
Westminster, CO 80021-6422  
Phone: (720) 354-8105 Fax: (720) 254-8105  
www.AuthorityAir.com Joe@AuthorityAir.com

Scale: 3/32" = 1'0"  
Page 1  
Uponor System Design Software  
12.1.04 RSU09203  
2013-Jan-02 16:45:08  
...Documents\Downloads\Sample 2....



**Main Floor**




**Job #: Sample Address**  
**Performed by Joe Colburn for:**  
 Sample Two  
 Sample Address  
 Denver, CO 80000  
 Phone: (720) 354-8105 Fax: (720) 354-8105  
 www.SampleWebsite.com Sample@Email.com


**Authority Air Designs, LLC.**  
 6608 W. 95th Place  
 Westminster, CO 80021-6422  
 Phone: (720) 354-8105 Fax: (720) 254-8105  
 www.AuthorityAir.com Joe@AuthorityAir.com

Scale: 3/32" = 1'0"

Page 2  
 Uponor System Design Software  
 12.1.04 RSU09203  
 2013-Jan-02 16:45:08  
 ...Documents\Downloads\Sample 2....




### Upper Floor




**Job #: Sample Address**  
**Performed by Joe Colburn for:**  
Sample Two  
Sample Address  
Denver, CO 80000  
Phone: (720) 354-8105 Fax: (720) 354-8105  
www.SampleWebsite.com Sample@Email.com

**Authority Air Designs, LLC.**  
6608 W. 95th Place  
Westminster, CO 80021-6422  
Phone: (720) 354-8105 Fax: (720) 254-8105  
www.AuthorityAir.com Joe@AuthorityAir.com

Scale: 3/32" = 1'0"  
Page 3  
Uponor System Design Software  
12.1.04 RSU09203  
2013-Jan-02 16:45:08  
...Documents\Downloads\Sample 2....




# Basement





**Job #: Sample Address**  
**Performed by Joe Colburn for:**  
 Sample Two  
 Sample Address  
 Denver, CO 80000  
 Phone: (720) 354-8105 Fax: (720) 354-8105  
 www.SampleWebsite.com Sample@Email.com

**Authority Air Designs, LLC.**  
 6608 W. 95th Place  
 Westminster, CO 80021-6422  
 Phone: (720) 354-8105 Fax: (720) 254-8105  
 www.AuthorityAir.com Joe@AuthorityAir.com

Scale: 1/8" = 1'0"  
 Page 1  
 Uponor System Design Software  
 12.1.04 RSU09203  
 2013-Jan-02 16:45:53  
 ...Documents\Downloads\Sample 2.rup




# Main Floor




**Job #: Sample Address**  
**Performed by Joe Colburn for:**  
 Sample Two  
 Sample Address  
 Denver, CO 80000  
 Phone: (720) 354-8105 Fax: (720) 354-8105  
 www.SampleWebsite.com Sample@Email.com

**Authority Air Designs, LLC.**  
 6608 W. 95th Place  
 Westminster, CO 80021-6422  
 Phone: (720) 354-8105 Fax: (720) 254-8105  
 www.AuthorityAir.com Joe@AuthorityAir.com

Scale: 1/8" = 1'0"  
 Page 2  
 Uponor System Design Software  
 12.1.04 RSU09203  
 2013-Jan-02 16:45:53  
 ...Documents\Downloads\Sample 2.rup




### Upper Floor




**Job #: Sample Address**  
**Performed by Joe Colburn for:**  
Sample Two  
Sample Address  
Denver, CO 80000  
Phone: (720) 354-8105 Fax: (720) 354-8105  
www.SampleWebsite.com Sample@Email.com


**Authority Air Designs, LLC.**  
6608 W. 95th Place  
Westminster, CO 80021-6422  
Phone: (720) 354-8105 Fax: (720) 254-8105  
www.AuthorityAir.com Joe@AuthorityAir.com

Scale: 1/8" = 1'0"  
Page 3  
Uponor System Design Software  
12.1.04 RSU09203  
2013-Jan-02 16:45:53  
...Documents\Downloads\Sample 2.rup





# Basement






# Main Floor







### Upper Floor

